

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of Diversion bund and Providing PCC canal at Satarkarwada Curpem in Sanguem Taluka.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1.1	F.73/14/2021						168.89		No. WRD/ SD I/ WD XII/ F.47/285/2021-22 DATED:- 12-01-2022
	F.73/15/2021	5/1/2022	3/2/2022	Retaining wall foundation	1.2.4	150kg/cm ²	164.44	165.92	
	F.73/16/2021						164.44		
1.2	F.73/17/2021						164.44		
	F.73/18/2021	5/1/2022	3/2/2022	Retaining wall foundation	1.2.4	150kg/cm ²	160.00	162.96	do
	F.73/19/2021						164.44		
2.1	F.73/20/2021						164.44		
	F.73/21/2021	7/1/2022	5/2/2022	Retaining wall above	1.2.4	150kg/cm ²	164.44	165.92	do
	F.73/22/2021						168.89		
2.2	F.73/23/2021						168.89		
	F.73/24/2021	7/1/2022	5/2/2022	Retaining wall above	1.2.4	150kg/cm ²	164.44	165.92	do
	F.73/25/2021						164.44		
3	F.73/26/2021						164.44		
	F.73/27/2021	10/1/2022	8/2/2022	Retaining wall above Ch. 0 m to 15 m	1.2.4	150kg/cm ²	160.00	162.96	do
	F.73/28/2021						164.44		
4	F.73/29/2021						240.00		
	F.73/30/2021	11/1/2022	9/2/2022	Canal Bed Ch 15 m to 30 m	1.1.5.3	200 kg/cm ²	231.11	235.56	do
	F.73/31/2021						235.56		
5	F.73/32/2021						240.00		
	F.73/33/2021	12/1/2022	10/2/2022	Canal wall Ch 30 m to 45 m	1.1.5.3	200 kg/cm ²	235.56	237.04	do
	F.73/34/2021						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER