

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Protection wall to the nallah side bank in Sy.No. 17/3-A at Cumborda in V.P. Verna in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.74/05/2021						164.44		No. WRD/SD I/ WD II/
	F.74/06/2021	10/1/2022	7/2/2022	Foundation	1.2.4	150 kg/cm2	164.44	164.44	F.Esst/718/2021-22
	F.74/07/2021						164.44		<b>DATED:- 01-02-2022</b>
1.2	F.74/08/2021						168.89		
	F.74/09/2021	10/1/2022	7/2/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/10/2021						164.44		
2.1	F.74/11/2021						164.44		
	F.74/12/2021	11/1/2022	8/2/2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	do
	F.74/13/2021						164.44		
2.2	F.74/14/2021						164.44		
	F.74/15/2021	11/1/2022	8/2/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/16/2021						168.89		
3.1	F.74/17/2021						168.89		
	F.74/18/2021	12/1/2022	9/2/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/19/2021						164.44		
3.2	F.74/20/2021						164.44		
	F.74/21/2021	12/1/2022	9/2/2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	do
	F.74/22/2021						164.44		
4.1	F.74/23/2021						164.44		
	F.74/24/2021	13-01-2022	10/2/2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	do
	F.74/25/2021						164.44		
4.2	F.74/26/2021						164.44		
	F.74/27/2021	13-01-2022	10/2/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/28/2021						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Protection wall to the nallah side bank in Sy.No. 17/3-A at Cumborda in V.P. Verna in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.74/29/2021						164.44		No. WRD/SD I/ WD II/
	F.74/30/2021	14-01-2022	11/2/2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	F.Esst/718/2021-22
	F.74/31/2021						164.44		<b>DATED:- 01-02-2022</b>
5.2	F.74/32/2021						164.44		
	F.74/33/2021	14-01-2022	11/2/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/34/2021						168.89		
6.1	F.74/35/2021						168.89		
	F.74/36/2021	15-01-2022	12/2/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/37/2021						164.44		
6.2	F.74/38/2021						164.44		
	F.74/39/2021	15-01-2022	12/2/2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	do
	F.74/40/2021						164.44		
7.1	F.74/41/2021						164.44		
	F.74/42/2021	17-01-2022	14-02-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	do
	F.74/43/2021						164.44		
7.2	F.74/44/2021						164.44		
	F.74/45/2021	17-01-2022	14-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/46/2021						168.89		
8.1	F.74/47/2021						168.89		
	F.74/48/2021	18-01-2022	15-02-2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	do
	F.74/49/2021						168.89		
8.2	F.74/50/2021						168.89		
	F.74/51/2021	18-01-2022	15-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/52/2021						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Protection wall to the nallah side bank in Sy.No. 17/3-A at Cumborda in V.P. Verna in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	F.74/53/2021						164.44		No. WRD/SD I/ WD II/
	F.74/54/2021	19-01-2022	16-02-2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	F.Esst/718/2021-22
	F.74/55/2021						164.44		<b>DATED:- 01-02-2022</b>
9.2	F.74/56/2021						164.44		
	F.74/57/2021	19-01-2022	16-02-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/58/2021						168.89		
10.1	F.74/59/2021						164.44		
	F.74/60/2021	20-01-2022	17-02-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/61/2021						168.89		
10.2	F.74/62/2021						168.89		
	F.74/63/2021	20-01-2022	17-02-2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	F.74/64/2021						164.44		
11.1	F.74/65/2021						164.44		
	F.74/66/2021	21-01-2022	18-02-2021	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/67/2021						168.89		
11.2	F.74/68/2021						168.89		
	F.74/69/2021	21-01-2022	18-02-2021	Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	F.74/70/2021						164.44		
12.1	F.74/71/2021						168.89		
	F.74/72/2021	22-01-2022	19-02-2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	do
	F.74/73/2021						164.44		
12.2	F.74/74/2021						168.89		
	F.74/75/2021	22-01-2022	19-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/76/2021						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Protection wall to the nallah side bank in Sy.No. 17/3-A at Cumborda in V.P. Verna in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
13.1	F.74/77/2021						164.44		No. WRD/SD I/ WD II/
	F.74/78/2021	24-01-2022	21-02-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	F.Esst/718/2021-22
	F.74/79/2021						164.44		<b>DATED:- 01-02-2022</b>
13.2	F.74/80/2021						164.44		
	F.74/81/2021	24-01-2022	21-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/82/2021						168.89		
14.1	F.74/83/2021						168.89		
	F.74/84/2021	25-01-2022	22-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/85/2021						164.44		
14.2	F.74/86/2021						164.44		
	F.74/87/2021	25-01-2022	22-02-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	do
	F.74/88/2021						164.44		
15.1	F.74/89/2021						164.44		
	F.74/90/2021	27-01-2022	24-02-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	do
	F.74/91/2021						164.44		
15.2	F.74/92/2021						164.44		
	F.74/93/2021	27-01-2022	24-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/94/2021						168.89		
16.1	F.74/95/2021						168.89		
	F.74/96/2021	28-01-2022	25-02-2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	do
	F.74/97/2021						168.89		
16.2	F.74/98/2021						168.89		
	F.74/99/2021	28-01-2022	25-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.74/100/2021						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**