

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Desilting and Improvement of existing drain at Azadnagar Margao- Goa.

**SAMPLE SENT BY:** AE, SD III, WD III, WRD, Gogol- Margao- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
1	F.21/04/2021						115.56		No.289/SD III/WDIII/
	F.21/05/2021	4/12/2021	11/12/2021	Foundation of drain	1.2.4	100 kg/cm <sup>2</sup>	120.00	118.52	WRD/2021-22/359.
	F.21/06/2021						120.00		<b>DATED: 07-12-2021.</b>
2	F.21/07/2021						115.56		
	F.21/08/2021	7/12/2021	14-12-2021	Side walls of the drain	1.2.4	100 kg/cm <sup>2</sup>	120.00	115.56	do
	F.21/09/2021						111.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**