

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of Retaining wall for the nallah in Sy.No. 320/1, 323/0 in V.P. Loutulim in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.75/23/2021						164.44		No. WRD/SD I/WD II/ F.Estt/722/2021-22 DATED:- 01-02-2022.
	F.75/24/2021	25-01-2022	22-02-2022	Foundation	1.2.4	150 kg/cm2	168.89	165.92	
	F.75/25/2021						164.44		
2	F.75/26/2021						164.44		do
	F.75/27/2021	26-01-2022	23-02-2022	Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.75/28/2021						164.44		
3	F.75/29/2021						168.89		do
	F.75/30/2021	27-01-2022	24-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.75/31/2021						164.44		
4	F.75/32/2021						164.44		do
	F.75/33/2021	28-01-2022	25-02-2022	Wall	1.2.4	150 kg/cm2	168.89	165.92	
	F.75/34/2021						164.44		
5	F.75/35/2021						164.44		do
	F.75/36/2021	30-01-2022	27-02-2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	
	F.75/37/2021						164.44		
6	F.75/38/2021						164.44		do
	F.75/39/2021	31-01-2022	28-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.75/40/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall for the nallah in Sy.No. 320/1, 323/0 in V.P. Loutulim in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	F.75/56/2021						168.89		No. WRD/SD I/WD II/
	F.75/57/2021	4/2/2021	4/3/2022	Foundation	1.2.4	150 kg/cm ²	164.44	165.92	F.Estt/732/2021-22
	F.75/58/2021						164.44		DATED:- 10-02-2022.
2	F.75/59/2021						164.44		
	F.75/60/2021	5/2/2022	5/3/2022	Foundation	1.2.4	150 kg/cm ²	168.89	165.92	do
	F.75/61/2021						164.44		
3	F.75/62/2021						164.44		
	F.75/63/2021	7/2/2022	7/3/2022	Wall	1.2.4	150 kg/cm ²	164.44	164.44	do
	F.75/64/2021						164.44		
4	F.75/65/2021						164.44		
	F.75/66/2021	8/2/2022	8/3/2022	Wall	1.2.4	150 kg/cm ²	164.44	165.92	do
	F.75/67/2021						168.89		
5	F.75/68/2021						164.44		
	F.75/69/2021	9/2/2022	9/3/2022	Wall	1.2.4	150 kg/cm ²	164.44	164.44	do
	F.75/70/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER