

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of retaining wall at Savoi Verem nallah from Shri Shripad Verekar house to Shri Vishnudas Shet Verekar house on both sides in V.P.
Verem Vaghurme in Priol Constituency in Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.76/11/2021						164.44		No. WRD/WD XI/ SD IV/ W.F. 446/507/2021-22. DATED: 07-03-2022
	F.76/12/2021	7/2/2022	7/3/2022	For Foundation	1.2.4	150 kg/cm2	168.89	165.92	
	F.76/13/2021						164.44		
1.2	F.76/14/2021						164.44		do
	F.76/15/2021	7/2/2022	7/3/2022	For Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.76/16/2021						164.44		
2.1	F.76/17/2021						168.89		do
	F.76/18/2021	8/2/2022	8/3/2022	For Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.76/19/2021						164.44		
2.2	F.76/20/2021						164.44		do
	F.76/21/2021	8/2/2022	8/3/2022	For Foundation	1.2.4	150 kg/cm2	168.89	165.92	
	F.76/22/2021						164.44		
3.1	F.76/23/2021						164.44		do
	F.76/24/2021	9/2/2022	9/3/2022	For Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.76/25/2021						164.44		
3.2	F.76/26/2021						164.44		do
	F.76/27/2021	9/2/2022	9/3/2022	For Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.76/28/2021						168.89		
4.1	F.76/29/2021						164.44		do
	F.76/30/2021	10/2/2022	11/3/2022	For Foundation	1.2.4	150 kg/cm2	168.89	165.92	
	F.76/31/2021						164.44		
4.2	F.76/32/2021						164.44		do
	F.76/33/2021	10/2/2022	11/3/2022	For Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.76/34/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER