

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement to the drainage system in Sy.No. 41/4 in Village Dramapur in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.81/06/2021						155.56		No. WRD/ SD I/ WD II/ F.Estt/850/2021-22. DATED: 28-03-2022
	F.81/07/2021	11/3/2022	8/4/2022	Foundation	1.2.4	150 kg/cm2	164.44	157.04	
	F.81/08/2021						151.11		
1.2	F.81/09/2021						160.00		do
	F.81/10/2021	11/3/2022	8/4/2022	Foundation	1.2.4	150 kg/cm2	155.56	158.52	
	F.81/11/2021						160.00		
2.1	F.81/12/2021						160.00		do
	F.81/13/2021	14-03-2022	11/4/2022	Foundation	1.2.4	150 kg/cm2	164.44	161.48	
	F.81/14/2021						160.00		
2.2	F.81/15/2021						153.33		do
	F.81/16/2021	14-03-2022	11/4/2022	Foundation	1.2.4	150 kg/cm2	164.44	159.26	
	F.81/17/2021						160.00		
3.1	F.81/18/2021						160.00		do
	F.81/19/2021	15-03-2022	12/4/2022	Foundation & Wall	1.2.4	150 kg/cm2	160.00	158.52	
	F.81/20/2021						155.56		
3.2	F.81/21/2021						168.89		do
	F.81/22/2021	15-03-2022	12/4/2022	Foundation & Wall	1.2.4	150 kg/cm2	155.56	160.00	
	F.81/23/2021						155.56		
4.1	F.81/24/2021						160.00		do
	F.81/25/2021	17-03-2022	14-04-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.81/26/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the drainage system in Sy.No. 41/4 in Village Dramapur in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.2	F.81/27/2021						155.56		No. WRD/ SD I/ WD II/ F.Estt/850/2021-22. DATED: 28-03-2022
	F.81/28/2021	17-03-2022	14-04-2022	Wall	1.2.4	150 kg/cm2	155.56	157.04	
	F.81/29/2021						160.00		
5.1	F.81/30/2021						155.56		
	F.81/31/2021	19-03-2022	16-04-2022	Wall	1.2.4	150 kg/cm2	160.00	158.52	do
	F.81/32/2021						160.00		
5.2	F.81/33/2021						155.56		
	F.81/34/2021	19-03-2022	16-04-2022	Wall	1.2.4	150 kg/cm2	164.44	160.00	do
	F.81/35/2021						160.00		
6.1	F.81/36/2021						155.56		
	F.81/37/2021	21-03-2022	18-04-2022	Wall	1.2.4	150 kg/cm2	151.11	157.04	do
	F.81/38/2021						164.44		
6.2	F.81/39/2021						155.56		
	F.81/40/2021	21-03-2022	18-04-2022	Wall	1.2.4	150 kg/cm2	168.89	158.52	do
	F.81/41/2021						151.11		
7.1	F.81/42/2021						164.44		
	F.81/43/2021	23-03-2022	20-04-2022	Wall	1.2.4	150 kg/cm2	164.44	160.00	do
	F.81/44/2021						151.11		
7.2	F.81/45/2021						151.11		
	F.81/46/2021	23-03-2022	20-04-2022	Wall	1.2.4	150 kg/cm2	160.00	158.52	do
	F.81/47/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER