

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement and Development of existing pond at Hodarwada, Curchorem in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.101/06/2021						155.56		No. WRD/ WD XII/ SD V/ F.15/122/2021-22. DATED: 10-12-2022.
	F.101/07/2021	3/12/2021	31-12-2021	Foundation	1.2.4	150 kg/cm2	155.56	154.08	
	F.101/08/2021						151.11		
1.2	F.101/09/2021						160.00		do
	F.101/10/2021	3/12/2021	31-12-2021	Foundation	1.2.4	150 kg/cm2	155.56	157.04	
	F.101/11/2021						155.56		
1.3	F.101/12/2021						160.00		do
	F.101/13/2021	3/12/2021	31-12-2021	Foundation	1.2.4	150 kg/cm2	160.00	160.00	
	F.101/14/2021						160.00		
1.4	F.101/15/2021						155.56		do
	F.101/16/2021	3/12/2021	31-12-2021	Foundation	1.2.4	150 kg/cm2	164.44	161.48	
	F.101/17/2021						164.44		
2.1	F.101/18/2021						160.00		do
	F.101/19/2021	4/12/2021	1/1/2022	1st Lift	1.2.4	150 kg/cm2	160.00	158.52	
	F.101/20/2021						155.56		
2.2	F.101/21/2021						168.89		do
	F.101/22/2021	4/12/2021	1/1/2022	1st Lift	1.2.4	150 kg/cm2	155.56	158.52	
	F.101/23/2021						151.11		
3.1	F.101/24/2021						160.00		do
	F.101/25/2021	6/12/2021	3/1/2022	2nd Lift	1.2.4	150 kg/cm2	160.00	161.48	
	F.101/26/2021						164.44		
3.2	F.101/27/2021						168.89		do
	F.101/28/2021	6/12/2021	3/1/2022	2nd Lift	1.2.4	150 kg/cm2	155.56	158.52	
	F.101/29/2021						151.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement and Development of existing pond at Hodarwada, Curchorem in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.101/30/2021						155.56		No. WRD/ WD XII/ SD V/ F.15/122/2021-22. DATED: 10-12-2022.
	F.101/31/2021	7/12/2021	4/1/2022	3rd Lift	1.2.4	150 kg/cm2	151.11	155.56	
	F.101/32/2021						160.00		
4.2	F.101/33/2021						155.56		do
	F.101/34/2021	7/12/2021	4/1/2022	3rd Lift	1.2.4	150 kg/cm2	151.11	154.08	
	F.101/35/2021						155.56		
5.1	F.101/36/2021						155.56		do
	F.101/37/2021	8/12/2021	5/1/2022	4th Lift	1.2.4	150 kg/cm2	160.00	157.04	
	F.101/38/2021						155.56		
5.2	F.101/39/2021						155.56		do
	F.101/40/2021	8/12/2021	5/1/2022	4th Lift	1.2.4	150 kg/cm2	151.11	152.59	
	F.101/41/2021						151.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER