

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to nallah from shri. Ashok Bhivshet bar to Kindir Manus at Varchawada in Village Morjim in Pernem Taluka.

**SAMPLE SENT BY:** AE, SD III, WD I, WRD, Pernem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.108/06/2021						124.44		No.MI/SD III/WD I/ F.58/2022-23/05. <b>DATED:- 05-04-2022</b>
	F.108/07/2021	18-03-2022	15-04-2022	Ch.0.00 to 100.00 (base) both sides	1.3.6	100kg/cm2	120.00	124.44	
	F.108/08/2021						128.89		
2	F.108/09/2021						128.89		do
	F.108/10/2021	19-03-2022	16-04-2022	Ch.100.00 to 180.00 (base) both sides	1.3.6	100kg/cm2	124.44	125.92	
	F.108/11/2021						124.44		
3.1	F.108/12/2021						128.89		do
	F.108/13/2021	19-03-2022	16-04-2022	Ch 0.00 to 45.00 (1) both side	1.3.6	100kg/cm2	124.44	124.44	
	F.108/14/2021						120.00		
3.2	F.108/15/2021						168.89		do
	F.108/16/2021	19-03-2022	16-04-2022	Ch 0.00 to 45.00 (1) both side	1.2.4	150kg/cm2	164.44	165.92	
	F.108/17/2021						164.44		
4	F.108/18/2021						164.44		do
	F.108/19/2021	20-03-2022	17-04-2022	Ch.180.00 to 250.00 (1)	1.2.4	150kg/cm2	160.00	162.96	
	F.108/20/2021						164.44		
5.1	F.108/21/2021						168.89		do
	F.108/22/2021	20-03-2022	17-04-2022	Ch. 45.00 to 100.00 (1) both side	1.2.4	150kg/cm2	160.00	164.44	
	F.108/23/2021						164.44		
5.2	F.108/24/2021						164.44		do
	F.108/25/2021	20-03-2022	17-04-2022	Ch. 45.00 to 100.00 (1) both side	1.2.4	150kg/cm2	164.44	162.96	
	F.108/26/2021						160.00		
6.1	F.108/27/2021						164.44		do
	F.108/28/2021	21-03-2022	18-04-2022	Ch.0.00 to 45.00 (2) both side	1.2.4	150kg/cm2	164.44	164.44	
	F.108/29/2021						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of protection wall to nallah from shri. Ashok Bhivshet bar to Kindir Manus at Varchawada in Village Morjim in Pernem Taluka.

**SAMPLE SENT BY:** AE, SD III, WD I, WRD, Pernem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.2	F.108/30/2021						168.89		No.MI/SD III/WD I/ F.58/2022-23/05. <b>DATED:- 05-04-2022</b>
	F.108/31/2021	21-03-2022	18-04-2022	Ch.0.00 to 45.00 (2) both side	1.2.4	150kg/cm2	164.44	167.41	
	F.108/32/2021						168.89		
7.1	F.108/33/2021						168.89		do
	F.108/34/2021	22-03-2022	19-04-2022	Ch.45.00 to 100.00 (2) both side	1.2.4	150kg/cm2	168.89	168.89	
	F.108/35/2021						168.89		
7.2	F.108/36/2021						173.33		do
	F.108/37/2021	22-03-2022	19-04-2022	Ch.45.00 to 100.00 (2) both side	1.2.4	150kg/cm2	168.89	168.89	
	F.108/38/2021						164.44		
8.1	F.108/39/2021						173.33		do
	F.108/40/2021	22-03-2022	19-04-2022	Ch.100.00 to 135.00 (1) both side	1.2.4	150kg/cm2	168.89	170.37	
	F.108/41/2021						168.89		
8.2	F.108/42/2021						160.00		do
	F.108/43/2021	22-03-2022	19-04-2022	Ch.100.00 to 135.00 (1) both side	1.2.4	150kg/cm2	164.44	162.96	
	F.108/44/2021						164.44		
9.1	F.108/45/2021						164.44		do
	F.108/46/2021	23-03-2022	20-04-2022	Ch.135.00 to 185.00 (1) both side	1.2.4	150kg/cm2	164.44	164.44	
	F.108/47/2021						164.44		
9.2	F.108/48/2021						164.44		do
	F.108/49/2021	23-03-2022	20-04-2022	Ch.135.00 to 185.00 (1) both side	1.2.4	150kg/cm2	164.44	165.92	
	F.108/50/2021						168.89		
10.1	F.108/51/2021						164.44		do
	F.108/52/2021	24-03-2022	21-04-2022	Ch.185.00 to 230.00 (1) both side	1.2.4	150kg/cm2	160.00	162.96	
	F.108/53/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of protection wall to nallah from shri. Ashok Bhivshet bar to Kindir Manus at Varchawada in Village Morjim in Pernem Taluka.

**SAMPLE SENT BY:** AE, SD III, WD I, WRD, Pernem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
10.2	F.108/54/2021						164.44		No.MI/SD III/WD I/ F.58/2022-23/05. <b>DATED:- 05-04-2022</b>
	F.108/55/2021	24-03-2022	21-04-2022	Ch.185.00 to 230.00 (1) both side	1.2.4	150kg/cm2	164.44	164.44	
	F.108/56/2021						164.44		
11.1	F.108/57/2021						168.89		
	F.108/58/2021	25-03-2022	22-04-2022	Ch.230.00 to 250.00 (1) both side	1.2.4	150kg/cm2	164.44	165.92	do
	F.108/59/2021						164.44		
11.2	F.108/60/2021						164.44		
	F.108/61/2021	25-03-2022	22-04-2022	Ch.230.00 to 250.00 (1) both side	1.2.4	150kg/cm2	160.00	162.96	do
	F.108/62/2021						164.44		
12.1	F.108/63/2021						164.44		
	F.108/64/2021	26-03-2022	23-04-2022	Ch.100.00 to 155.00 (2) both side	1.2.4	150kg/cm2	164.44	165.92	do
	F.108/65/2021						168.89		
12.2	F.108/66/2021						168.89		
	F.108/67/2021	26-03-2022	23-04-2022	Ch.100.00 to 155.00 (2) both side	1.2.4	150kg/cm2	164.44	165.92	do
	F.108/68/2021						164.44		
13.1	F.108/69/2021						164.44		
	F.108/70/2021	27-03-2022	24-04-2022	Ch.155.00 to 190.00 (2) both side	1.2.4	150kg/cm2	160.00	162.96	do
	F.108/71/2021						164.44		
13.2	F.108/72/2021						164.44		
	F.108/73/2021	27-03-2022	24-04-2022	Ch.155.00 to 190.00 (2) both side	1.2.4	150kg/cm2	160.00	162.96	do
	F.108/74/2021						164.44		
14.1	F.108/75/2021						164.44		
	F.108/76/2021	28-03-2022	25-04-2022	Ch.190.00 to 225.00 (2) both side	1.2.4	150kg/cm2	164.44	165.92	do
	F.108/77/2021						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to nallah from shri. Ashok Bhivshet bar to Kindir Manus at Varchawada in Village Morjim in Pernem Taluka.

**SAMPLE SENT BY:** AE, SD III, WD I, WRD, Pernem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
14.2	F.108/78/2021						164.44		No.MI/SD III/WD I/ F.58/2022-23/05. <b>DATED:- 05-04-2022</b>
	F.108/79/2021	28-03-2022	25-04-2022	Ch.190.00 to 225.00 (2) both side	1.2.4	150kg/cm2	160.00	162.96	
	F.108/80/2021						164.44		
15.1	F.108/81/2021						164.44		
	F.108/82/2021	29-03-2022	26-04-2022	Ch.0.00 to 60.00 (3) both side	1.2.4	150kg/cm2	164.44	165.92	do
	F.108/83/2021						168.89		
15.2	F.108/84/2021						164.44		
	F.108/85/2021	29-03-2022	26-04-2022	Ch.0.00 to 60.00 (3) both side	1.2.4	150kg/cm2	164.44	165.92	do
	F.108/86/2021						168.89		
16.1	F.108/87/2021						168.89		
	F.108/88/2021	1/4/2022	29-04-2022	Ch. 60.00 to 110.00 (3) both side	1.2.4	150kg/cm2	168.89	167.41	do
	F.108/89/2021						164.44		
16.2	F.108/90/2021						164.44		
	F.108/91/2021	1/4/2022	29-04-2022	Ch. 60.00 to 110.00 (3) both side	1.2.4	150kg/cm2	164.44	165.92	do
	F.108/92/2021						168.89		
17.1	F.108/93/2021						168.89		
	F.108/94/2021	1/4/2022	29-04-2022	Ch. 110.00 to 160.00 (3) both side	1.2.4	150kg/cm2	168.89	167.41	do
	F.108/95/2021						164.44		
17.2	F.108/96/2021						168.89		
	F.108/97/2021	1/4/2022	29-04-2022	Ch. 110.00 to 160.00 (3) both side	1.2.4	150kg/cm2	168.89	167.41	do
	F.108/98/2021						164.44		
18.1	F.108/99/2021						168.89		
	F.108/100/2021	1/4/2022	29-04-2022	Ch. 160.00 to 220.00 (3) both side	1.2.4	150kg/cm2	164.44	165.92	do
	F.108/101/2021						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to nallah from shri. Ashok Bhivshet bar to Kindir Manus at Varchawada in Village Morjim in Pernem Taluka.

**SAMPLE SENT BY:** AE, SD III, WD I, WRD, Pernem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
18.2	F.108/102/2021						164.44		No.MI/SD III/WD I/ F.58/2022-23/05. <b>DATED:- 05-04-2022</b>
	F.108/103/2021	1/4/2022	29-04-2022	Ch. 160.00 to 220.00 (3) both side	1.2.4	150kg/cm2	164.44	164.44	
	F.108/104/2021						164.44		
19.1	F.108/105/2021						164.44		do
	F.108/106/2021	2/4/2022	30-04-2022	Ch. 220.00 to 250.00 (3) both side	1.2.4	150kg/cm2	164.44	165.92	
	F.108/107/2021						168.89		
19.2	F.108/108/2021						168.89		do
	F.108/109/2021	2/4/2022	30-04-2022	Ch. 220.00 to 250.00 (3) both side	1.2.4	150kg/cm2	168.89	167.41	
	F.108/110/2021						164.44		
20.1	F.108/111/2021						164.44		do
	F.108/112/2021	2/4/2022	30-04-2022	Ch. 0.00 to 100.00 (4) both side	1.2.4	150kg/cm2	164.44	165.92	
	F.108/113/2021						168.89		
20.2	F.108/114/2021						168.89		do
	F.108/115/2021	2/4/2022	30-04-2022	Ch. 0.00 to 100.00 (4) both side	1.2.4	150kg/cm2	168.89	167.41	
	F.108/116/2021						164.44		
21.1	F.108/117/2021						168.89		do
	F.108/118/2021	3/4/2022	1/5/2022	Ch. 100.00 to 190.00 (4) both side	1.2.4	150kg/cm2	168.89	168.89	
	F.108/119/2021						168.89		
21.2	F.108/120/2021						168.89		do
	F.108/121/2021	3/4/2022	1/5/2022	Ch. 100.00 to 190.00 (4) both side	1.2.4	150kg/cm2	168.89	167.41	
	F.108/122/2021						164.44		
22.1	F.108/123/2021						168.89		do
	F.108/124/2021	4/4/2022	2/5/2022	Ch. 190.00 to 250.00 (4) both side	1.2.4	150kg/cm2	164.44	165.92	
	F.108/125/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to nallah from shri. Ashok Bhivshet bar to Kindir Manus at Varchawada in Village Morjim in Pernem Taluka.

**SAMPLE SENT BY:** AE, SD III, WD I, WRD, Pernem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
22.2	F.108/126/2021						168.89		No.MI/SD III/WD I/
	F.108/127/2021	4/4/2022	2/5/2022	Ch. 190.00 to 250.00 (4) both side	1.2.4	150kg/cm2	168.89	167.41	F.58/2022-23/05.
	F.108/128/2021						164.44		<b>DATED:- 05-04-2022</b>

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**