

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah from Holy cross Sulabhat in Ward No.8 to Caitani house at Arebhat in V.P. Agassaim St. Andre Constituency.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.109/06/2021						168.89		No.SD IV/ WD I/ WRD/ F.38/2022-23/32. DATED:- 13-04-2022.
	F.109/07/2021	23-03-2022	20-04-2022	RHS Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.109/08/2021						168.89		
1.2	F.109/09/2021						164.44		
	F.109/10/2021	23-03-2022	20-04-2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.109/11/2021						168.89		
1.3	F.109/12/2021						164.44		
	F.109/13/2021	23-03-2022	20-04-2022	RHS Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	F.109/14/2021						168.89		
1.4	F.109/15/2021						168.89		
	F.109/16/2021	23-03-2022	20-04-2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	F.109/17/2021						168.89		
2.1	F.109/18/2021						168.89		
	F.109/19/2021	24-03-2022	21-04-2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	F.109/20/2021						168.89		
2.2	F.109/21/2021						168.89		
	F.109/22/2021	24-03-2022	21-04-2022	RHS Foundation	1.2.4	150 kg/cm2	168.89	168.89	do
	F.109/23/2021						168.89		
2.3	F.109/24/2021						168.89		
	F.109/25/2021	24-03-2022	21-04-2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	F.109/26/2021						168.89		
2.4	F.109/27/2021						168.89		
	F.109/28/2021	24-03-2022	21-04-2022	RHS Foundation	1.2.4	150 kg/cm2	168.89	168.89	do
	F.109/29/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah from Holy cross Sulabhat in Ward No.8 to Caitani house at Arebhat in V.P. Agassaim St. Andre Constituency.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.109/30/2021						168.89		No.SD IV/ WD I/ WRD/ F.38/2022-23/32. DATED:- 13-04-2022.
	F.109/31/2021	25-03-2022	22-04-2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	F.109/32/2021						168.89		
3.2	F.109/33/2021						168.89		do
	F.109/34/2021	25-03-2022	22-04-2022	LHS Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.109/35/2021						168.89		
3.3	F.109/36/2021						173.33		do
	F.109/37/2021	25-03-2022	22-04-2022	LHS Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.109/38/2021						164.44		
3.4	F.109/39/2021						173.33		do
	F.109/40/2021	25-03-2022	22-04-2022	LHS Foundation	1.2.4	150 kg/cm2	168.89	170.37	
	F.109/41/2021						168.89		
4.1	F.109/42/2021						160.00		do
	F.109/43/2021	26-03-2022	23-04-2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	162.96	
	F.109/44/2021						164.44		
4.2	F.109/45/2021						164.44		do
	F.109/46/2021	26-03-2022	23-04-2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.109/47/2021						164.44		
4.3	F.109/48/2021						164.44		do
	F.109/49/2021	26-03-2022	23-04-2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.109/50/2021						168.89		
4.4	F.109/51/2021						164.44		do
	F.109/52/2021	26-03-2022	23-04-2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.109/53/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah from Holy cross Sulabhat in Ward No.8 to Caitani house at Arebhat in V.P. Agassaim St. Andre Constituency.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.109/54/2021						168.89		No.SD IV/ WD I/ WRD/ F.38/2022-23/32. DATED:- 13-04-2022.
	F.109/55/2021	28-03-2022	25-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	168.89	168.89	
	F.109/56/2021						168.89		
5.2	F.109/57/2021						164.44		do
	F.109/58/2021	28-03-2022	25-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.109/59/2021						168.89		
5.3	F.109/60/2021						164.44		do
	F.109/61/2021	28-03-2022	25-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	168.89	167.41	
	F.109/62/2021						168.89		
5.4	F.109/63/2021						168.89		do
	F.109/64/2021	28-03-2022	25-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	164.44	167.41	
	F.109/65/2021						168.89		
6.1	F.109/66/2021						168.89		do
	F.109/67/2021	29-03-2022	26-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	164.44	167.41	
	F.109/68/2021			LHS 1st Lift			168.89		
6.2	F.109/69/2021						168.89		do
	F.109/70/2021	29-03-2022	26-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	168.89	168.89	
	F.109/71/2021			LHS 1st Lift			168.89		
6.3	F.109/72/2021						168.89		do
	F.109/73/2021	29-03-2022	26-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	164.44	167.41	
	F.109/74/2021			LHS 1st Lift			168.89		
6.4	F.109/75/2021						168.89		do
	F.109/76/2021	29-03-2022	26-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	168.89	168.89	
	F.109/77/2021			LHS 1st Lift			168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah from Holy cross Sulabhat in Ward No.8 to Caitani house at Arebhat in V.P. Agassaim St. Andre Constituency.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
7.1	F.109/78/2021						168.89		No.SD IV/ WD I/ WRD/ F.38/2022-23/32. DATED:- 13-04-2022.
	F.109/79/2021	30-03-2022	27-04-2022	LHS 1st Lift	1.2.4	150 kg/cm2	164.44	167.41	
	F.109/80/2021						168.89		
7.2	F.109/81/2021						168.89		do
	F.109/82/2021	30-03-2022	27-04-2022	LHS 1st Lift	1.2.4	150 kg/cm2	168.89	168.89	
	F.109/83/2021						168.89		
7.3	F.109/84/2021						173.33		do
	F.109/85/2021	30-03-2022	27-04-2022	LHS 1st Lift	1.2.4	150 kg/cm2	168.89	168.89	
	F.109/86/2021						164.44		
7.4	F.109/87/2021						173.33		do
	F.109/88/2021	30-03-2022	27-04-2022	LHS 1st Lift	1.2.4	150 kg/cm2	168.89	170.37	
	F.109/89/2021						168.89		
8.1	F.109/90/2021						160.00		do
	F.109/91/2021	31-03-2022	28-04-2022	RHS 2nd Lift	1.2.4	150 kg/cm2	164.44	162.96	
	F.109/92/2021						164.44		
8.2	F.109/93/2021						164.44		do
	F.109/94/2021	31-03-2022	28-04-2022	RHS 2nd Lift	1.2.4	150 kg/cm2	164.44	164.44	
	F.109/95/2021						164.44		
8.3	F.109/96/2021						164.44		do
	F.109/97/2021	31-03-2022	28-04-2022	RHS 2nd Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.109/98/2021						168.89		
8.4	F.109/99/2021						164.44		do
	F.109/100/2021	31-03-2022	28-04-2022	RHS 2nd Lift	1.2.4	150 kg/cm2	168.89	165.92	
	F.109/101/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah from Holy cross Sulabhat in Ward No.8 to Caitani house at Arebhat in V.P. Agassaim St. Andre Constituency.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	F.109/102/2021						168.89		No.SD IV/ WD I/ WRD/ F.38/2022-23/32. DATED:- 13-04-2022.
	F.109/103/2021	1/4/2022	29-04-2022	LHS 2nd Lift	1.2.4	150 kg/cm2	164.44	167.41	
	F.109/104/2021						168.89		
9.2	F.109/105/2021						164.44		do
	F.109/106/2021	1/4/2022	29-04-2022	LHS 2nd Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.109/107/2021						168.89		
9.3	F.109/108/2021						164.44		do
	F.109/109/2021	1/4/2022	29-04-2022	LHS 2nd Lift	1.2.4	150 kg/cm2	168.89	167.41	
	F.109/110/2021						168.89		
10.1	F.109/111/2021						164.44		do
	F.109/112/2021	2/4/2022	30-04-2022	RHS 3rd Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.109/113/2021						168.89		
10.2	F.109/114/2021						168.89		do
	F.109/115/2021	2/4/2022	30-04-2022	RHS 3rd Lift	1.2.4	150 kg/cm2	164.44	167.41	
	F.109/116/2021						168.89		
10.3	F.109/117/2021						168.89		do
	F.109/118/2021	2/4/2022	30-04-2022	RHS 3rd Lift	1.2.4	150 kg/cm2	164.44	167.41	
	F.109/119/2021						168.89		
11.1	F.109/120/2021						168.89		do
	F.109/121/2021	4/4/2022	2/5/2022	LHS 3rd Lift	1.2.4	150 kg/cm2	168.89	168.89	
	F.109/122/2021						168.89		
11.2	F.109/123/2021						173.33		do
	F.109/124/2021	4/4/2022	2/5/2022	LHS 3rd Lift	1.2.4	150 kg/cm2	168.89	168.89	
	F.109/125/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah from Holy cross Sulabhat in Ward No.8 to Caitani house at Arebhat in V.P. Agassaim St. Andre Constituency.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
11.3	F.109/126/2021						168.89		No.SD IV/ WD I/ WRD/
	F.109/127/2021	4/4/2022	2/5/2022	LHS 3rd Lift	1.2.4	150 kg/cm2	168.89	168.89	F.38/2022-23/32.
	F.109/128/2021						168.89		DATED:- 13-04-2022.

JUNIOR ENGINEER.

ASSISTANT ENGINEER