

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah from Babu house to Prakash house at Mongada in V.P. Goa Velha in St. Andre Constituency.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.110/06/2021						168.89		No.SD IV/ WD I/ WRD/ F.38/2022-23/33. DATED:- 13-04-2022.
	F.110/07/2021	24-03-2022	21-04-2022	RHS Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.110/08/2021						168.89		
1.2	F.110/09/2021						164.44		
	F.110/10/2021	24-03-2022	21-04-2022	RHS Foundation	1.2.4	150 kg/cm2	173.33	168.89	do
	F.110/11/2021						168.89		
1.3	F.110/12/2021						164.44		
	F.110/13/2021	24-03-2022	21-04-2022	RHS Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	F.110/14/2021						168.89		
1.4	F.110/15/2021						168.89		
	F.110/16/2021	24-03-2022	21-04-2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	F.110/17/2021						168.89		
1.5	F.110/18/2021						168.89		
	F.110/19/2021	24-03-2022	21-04-2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	F.110/20/2021						168.89		
2.1	F.110/21/2021						168.89		
	F.110/22/2021	25-03-2022	22-04-2022	RHS Foundation	1.2.4	150 kg/cm2	168.89	168.89	do
	F.110/23/2021			LHS Foundation			168.89		
2.2	F.110/24/2021						168.89		
	F.110/25/2021	25-03-2022	22-04-2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	F.110/26/2021			LHS Foundation			168.89		
2.3	F.110/27/2021						168.89		
	F.110/28/2021	25-03-2022	22-04-2022	RHS Foundation	1.2.4	150 kg/cm2	168.89	168.89	do
	F.110/29/2021			LHS Foundation			168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah from Babu house to Prakash house at Mongada in V.P. Goa Velha in St. Andre Constituency.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
2.4	F.110/30/2021						168.89		No.SD IV/ WD I/ WRD/ F.38/2022-23/33. DATED:- 13-04-2022.
	F.110/31/2021	25-03-2022	22-04-2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	F.110/32/2021			LHS Foundation			168.89		
2.5	F.110/33/2021						168.89		do
	F.110/34/2021	25-03-2022	22-04-2022	RHS Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.110/35/2021			LHS Foundation			168.89		
3.1	F.110/36/2021						173.33		do
	F.110/37/2021	26-03-2022	23-04-2022	LHS Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.110/38/2021						164.44		
3.2	F.110/39/2021						173.33		do
	F.110/40/2021	26-03-2022	23-04-2022	LHS Foundation	1.2.4	150 kg/cm2	168.89	170.37	
	F.110/41/2021						168.89		
3.3	F.110/42/2021						168.89		do
	F.110/43/2021	26-03-2022	23-04-2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.110/44/2021						164.44		
3.4	F.110/45/2021						164.44		do
	F.110/46/2021	26-03-2022	23-04-2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.110/47/2021						164.44		
3.5	F.110/48/2021						164.44		do
	F.110/49/2021	26-03-2022	23-04-2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.110/50/2021						168.89		
4.1	F.110/51/2021						164.44		do
	F.110/52/2021	28-03-2022	25-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	164.44	164.44	
	F.110/53/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah from Babu house to Prakash house at Mongada in V.P. Goa Velha in St. Andre Constituency.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.2	F.110/54/2021						168.89		No.SD IV/ WD I/ WRD/ F.38/2022-23/33. DATED:- 13-04-2022.
	F.110/55/2021	28-03-2022	25-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	168.89	168.89	
	F.110/56/2021						168.89		
4.3	F.110/57/2021						164.44		
	F.110/58/2021	28-03-2022	25-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	173.33	168.89	do
	F.110/59/2021						168.89		
4.4	F.110/60/2021						164.44		
	F.110/61/2021	28-03-2022	25-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	168.89	167.41	do
	F.110/62/2021						168.89		
4.5	F.110/63/2021						168.89		
	F.110/64/2021	28-03-2022	25-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	173.33	170.37	do
	F.110/65/2021						168.89		
5.1	F.110/66/2021						168.89		
	F.110/67/2021	29-03-2022	26-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	164.44	167.41	do
	F.110/68/2021			LHS 1st Lift			168.89		
5.2	F.110/69/2021						168.89		
	F.110/70/2021	29-03-2022	26-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	168.89	168.89	do
	F.110/71/2021			LHS 1st Lift			168.89		
5.3	F.110/72/2021						168.89		
	F.110/73/2021	29-03-2022	26-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	164.44	167.41	do
	F.110/74/2021			LHS 1st Lift			168.89		
5.4	F.110/75/2021						168.89		
	F.110/76/2021	29-03-2022	26-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	168.89	168.89	do
	F.110/77/2021			LHS 1st Lift			168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah from Babu house to Prakash house at Mongada in V.P. Goa Velha in St. Andre Constituency.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.4	F.110/78/2021						168.89		No.SD IV/ WD I/ WRD/ F.38/2022-23/33. DATED:- 13-04-2022.
	F.110/79/2021	29-03-2022	26-04-2022	RHS 1st Lift	1.2.4	150 kg/cm2	173.33	170.37	
	F.110/80/2021			LHS 1st Lift			168.89		
6.1	F.110/81/2021						168.89		
	F.110/82/2021	30-03-2022	27-04-2022	LHS 1st Lift	1.2.4	150 kg/cm2	168.89	168.89	do
	F.110/83/2021						168.89		
6.2	F.110/84/2021						173.33		
	F.110/85/2021	30-03-2022	27-04-2022	LHS 1st Lift	1.2.4	150 kg/cm2	168.89	168.89	do
	F.110/86/2021						164.44		
6.3	F.110/87/2021						173.33		
	F.110/88/2021	30-03-2022	27-04-2022	LHS 1st Lift	1.2.4	150 kg/cm2	168.89	170.37	do
	F.110/89/2021						168.89		
6.4	F.110/90/2021						173.33		
	F.110/91/2021	30-03-2022	27-04-2022	LHS 1st Lift	1.2.4	150 kg/cm2	164.44	167.40	do
	F.110/92/2021						164.44		
6.5	F.110/93/2021						164.44		
	F.110/94/2021	30-03-2022	27-04-2022	LHS 1st Lift	1.2.4	150 kg/cm2	164.44	164.44	do
	F.110/95/2021						164.44		
7.1	F.110/96/2021						164.44		
	F.110/97/2021	31-03-2022	28-04-2022	RHS 2nd Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	F.110/98/2021						168.89		
7.2	F.110/99/2021						164.44		
	F.110/100/2021	31-03-2022	28-04-2022	RHS 2nd Lift	1.2.4	150 kg/cm2	168.89	165.92	do
	F.110/101/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah from Babu house to Prakash house at Mongada in V.P. Goa Velha in St. Andre Constituency.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
7.3	F.110/102/2021						168.89		No.SD IV/ WD I/ WRD/ F.38/2022-23/33. DATED:- 13-04-2022.
	F.110/103/2021	31-03-2022	28-04-2022	RHS 2nd Lift	1.2.4	150 kg/cm2	164.44	167.41	
	F.110/104/2021						168.89		
7.4	F.110/105/2021						164.44		do
	F.110/106/2021	31-03-2022	28-04-2022	RHS 2nd Lift	1.2.4	150 kg/cm2	173.33	168.89	
	F.110/107/2021						168.89		
8.1	F.110/108/2021						164.44		do
	F.110/109/2021	1/4/2022	29-04-2022	LHS 2nd Lift	1.2.4	150 kg/cm2	168.89	167.41	
	F.110/110/2021						168.89		
8.2	F.110/111/2021						164.44		do
	F.110/112/2021	1/4/2022	29-04-2022	LHS 2nd Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.110/113/2021						168.89		
8.3	F.110/114/2021						168.89		do
	F.110/115/2021	1/4/2022	29-04-2022	LHS 2nd Lift	1.2.4	150 kg/cm2	164.44	167.41	
	F.110/116/2021						168.89		
8.4	F.110/117/2021						168.89		do
	F.110/118/2021	1/4/2022	29-04-2022	LHS 2nd Lift	1.2.4	150 kg/cm2	164.44	167.41	
	F.110/119/2021						168.89		
9.1	F.110/120/2021						168.89		do
	F.110/121/2021	2/4/2022	30-04-2022	RHS 3rd Lift	1.2.4	150 kg/cm2	168.89	168.89	
	F.110/122/2021						168.89		
9.2	F.110/123/2021						173.33		do
	F.110/124/2021	2/4/2022	30-04-2022	RHS 3rd Lift	1.2.4	150 kg/cm2	168.89	168.89	
	F.110/125/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah from Babu house to Prakash house at Mongada in V.P. Goa Velha in St. Andre Constituency.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.3	F.110/126/2021						168.89		No.SD IV/ WD I/ WRD/ F.38/2022-23/33. DATED:- 13-04-2022.
	F.110/127/2021	2/4/2022	30-04-2022	RHS 3rd Lift	1.2.4	150 kg/cm2	168.89	168.89	
	F.110/128/2021						168.89		
9.4	F.110/129/2021						164.44		do
	F.110/130/2021	2/4/2022	30-04-2022	RHS 3rd Lift	1.2.4	150 kg/cm2	168.89	167.41	
	F.110/131/2021						168.89		
10.1	F.110/132/2021						168.89		do
	F.110/133/2021	4/4/2022	2/5/2022	LHS 3rd Lift	1.2.4	150 kg/cm2	164.44	167.41	
	F.110/134/2021						168.89		
10.2	F.110/135/2021						168.89		do
	F.110/136/2021	4/4/2022	2/5/2022	LHS 3rd Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.110/137/2021						164.44		
10.3	F.110/138/2021						164.44		do
	F.110/139/2021	4/4/2022	2/5/2022	LHS 3rd Lift	1.2.4	150 kg/cm2	168.89	165.92	
	F.110/140/2021						164.44		
10.4	F.110/141/2021						164.44		do
	F.110/142/2021	4/4/2022	2/5/2022	LHS 3rd Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.110/143/2021						168.89		
11.1	F.110/144/2021						231.11		do
	F.110/145/2021	4/4/2022	2/5/2022	Slabs	1.2.4	200 kg/cm2	231.11	231.11	
	F.110/146/2021						231.11		
11.2	F.110/147/2021						240.00		do
	F.110/148/2021	4/4/2022	2/5/2022	Slabs	1.2.4	200 kg/cm2	231.11	235.56	
	F.110/149/2021						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER