

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection wall for nallah in Sy.No. 77 at Mullos in V.P. Paroda in Cuncolim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.24/05/2021						168.89		No. WRD/SD I/ WD II/ F.Esst/399/2021-22 DATED:- 07-12-2021
	F.24/06/2021	22-11-2021	20-12-2021	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.24/07/2021						168.89		
2	F.24/08/2021						164.44		do
	F.24/09/2021	24-11-2021	22-12-2021	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.24/10/2021						168.89		
3	F.24/11/2021						164.44		do
	F.24/12/2021	25-11-2021	23-12-2021	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.24/13/2021						168.89		
4	F.24/14/2021						168.89		do
	F.24/15/2021	27-11-2021	25-11-2021	Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	F.24/16/2021						168.89		
5	F.24/17/2021						168.89		do
	F.24/18/2021	29-11-2021	27-12-2021	Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	F.24/19/2021						168.89		
6.1	F.24/20/2021						168.89		do
	F.24/21/2021	1/12/2021	29-12-2021	Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.24/22/2021						168.89		
6.2	F.24/23/2021						168.89		do
	F.24/24/2021	1/12/2021	29-12-2021	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.24/25/2021						168.89		
7.1	F.24/26/2021						168.89		do
	F.24/27/2021	2/12/2021	30-12-2021	Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.24/28/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection wall for nallah in Sy.No. 77 at Mullos in V.P. Paroda in Cuncolim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
7.2	F.24/29/2021						168.89		No. WRD/SD I/ WD II/
	F.24/30/2021	2/12/2021	30-12-2021	Wall	1.2.4	150 kg/cm ²	164.44	167.41	F.Esst/399/2021-22
	F.24/31/2021						168.89		DATED:- 07-12-2021
8	F.24/32/2021						164.44		
	F.24/33/2021	4/12/2021	1/1/2022	Wall	1.2.4	150 kg/cm ²	164.44	165.92	do
	F.24/34/2021						168.89		
9	F.24/35/2021						164.44		
	F.24/36/2021	6/12/2021	3/1/2022	Wall	1.2.4	150 kg/cm ²	168.89	167.41	do
	F.24/37/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development of pond in Sy.No. 1/41 and Improvement of outlet in Village Sirlim of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.2	7877						168.89		No. WRD/SD I/ WD II/ F.Esst/137/2021-22 DATED:- 07-06-2021
	7878	22-05-2021	19-06-2021	Foundation & Wall	1.2.4	150 kg/cm2	164.44	167.41	
	7879						168.89		
6.3	7880						168.89		do
	7881	22-05-2021	19-06-2021	Foundation & Wall	1.2.4	150 kg/cm2	168.89	168.89	
	7882						168.89		
7.1	7883						173.33		do
	7884	24-05-2021	21-06-2021	Walls	1.2.4	150 kg/cm2	168.89	168.89	
	7885						164.44		
7.2	7886						173.33		do
	7887	24-05-2021	21-06-2021	Walls	1.2.4	150 kg/cm2	168.89	170.37	
	7888						168.89		
7.3	7889						160.00		do
	7890	24-05-2021	21-06-2021	Walls	1.2.4	150 kg/cm2	164.44	162.96	
	7891						164.44		
8.1	7892						164.44		do
	7893	25-05-2021	22-06-2021	Walls	1.2.4	150 kg/cm2	164.44	164.44	
	7894						164.44		
8.2	7895						164.44		do
	7896	25-05-2021	22-06-2021	Walls	1.2.4	150 kg/cm2	164.44	165.92	
	7897						168.89		
8.3	7898						164.44		do
	7899	25-05-2021	22-06-2021	Walls	1.2.4	150 kg/cm2	160.00	162.96	
	7900						164.44		

Sandip Parab
JUNIOR ENGINEER.

Pravin C Parsekar
ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development of pond in Sy.No. 1/41 and Improvement of outlet in Village Sirlim of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
9.1	7901						168.89		No. WRD/SD I/ WD II/ F.Esst/137/2021-22 DATED:- 07-06-2021
	7902	26-05-2021	23-06-2021	Walls	1.2.4	150 kg/cm ²	168.89	165.93	
	7903						160.00		
9.2	7904						164.44		
	7905	26-05-2021	23-06-2021	Walls	1.2.4	150 kg/cm ²	164.44	164.44	do
	7906						164.44		
9.3	7907						164.44		
	7908	26-05-2021	23-06-2021	Walls	1.2.4	150 kg/cm ²	164.44	164.44	do
	7909						164.44		
10.1	7910						164.44		
	7911	27-05-2021	24-06-2021	Walls	1.2.4	150 kg/cm ²	168.89	165.92	do
	7912						164.44		
10.2	7913						160.00		
	7914	27-05-2021	24-06-2021	Walls	1.2.4	150 kg/cm ²	164.44	162.96	do
	7915						164.44		
10.3	7916						164.44		
	7917	27-05-2021	24-06-2021	Walls	1.2.4	150 kg/cm ²	164.44	164.44	do
	7918						164.44		
11.1	7919						164.44		
	7920	28-05-2021	25-06-2021	Walls	1.2.4	150 kg/cm ²	168.89	165.92	do
	7921						164.44		
11.2	7922						168.89		
	7923	28-05-2021	25-06-2021	Walls	1.2.4	150 kg/cm ²	164.44	167.41	do
	7924						168.89		

Sandip Parab
JUNIOR ENGINEER.

Pravin C Parsekar
ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development of pond in Sy.No. 1/41 and Improvement of outlet in Village Sirlim of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
11.3	7925						168.89		No. WRD/SD I/ WD II/ F.Esst/137/2021-22 DATED:- 07-06-2021
	7926	28-05-2021	25-06-2021	Walls	1.2.4	150 kg/cm2	164.44	167.41	
	7927						168.89		
12.1	7928						168.89		do
	7929	29-05-2021	26-06-2021	Walls	1.2.4	150 kg/cm2	168.89	168.89	
	7930						168.89		
12.2	7931						173.33		do
	7932	29-05-2021	26-06-2021	Walls	1.2.4	150 kg/cm2	168.89	168.89	
	7933						164.44		
12.3	7934						173.33		do
	7935	29-05-2021	26-06-2021	Walls	1.2.4	150 kg/cm2	168.89	170.37	
	7936						168.89		
13.1	7937						160.00		do
	7938	30-05-2021	27-06-2021	Walls	1.2.4	150 kg/cm2	164.44	162.96	
	7939						164.44		
13.2	7940						164.44		do
	7941	30-05-2021	27-06-2021	Walls	1.2.4	150 kg/cm2	164.44	164.44	
	7942						164.44		
13.3	7943						164.44		do
	7944	30-05-2021	27-06-2021	Walls	1.2.4	150 kg/cm2	164.44	165.92	
	7945						168.89		

Sandip Parab
JUNIOR ENGINEER.

Pravin C Parsekar
ASSISTANT ENGINEER