

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall adjacent to Chalta No.155, PTS 150 at Modsai in Fatorda Constituency.

SAMPLE SENT BY: AE, SD III, WD II, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	F.113/06/2021						168.89		No.303/SD III/ WD III/
	F.113/07/2021	24-02-2022	24-03-2022	Wall Foundation	1.2.4	150 kg/cm ²	164.44	167.41	WRD/2022-23/541.
	F.113/08/2021						168.89		DATED:- 16-03-2022.
2	F.113/09/2021						168.89		
	F.113/10/2021	25-02-2022	25-03-2022	Wall above bed 1st lift	1.2.4	150 kg/cm ²	168.89	168.89	do
	F.113/11/2021						168.89		
3	F.113/12/2021						164.44		
	F.113/13/2021	26-02-2022	26-03-2022	Wall above bed 2nd lift	1.2.4	150 kg/cm ²	168.89	165.92	do
	F.113/14/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER