

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Protection wall for nallah in Sy.No. 198 in Village Guirdolim in Cuncolim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.114/01/2021						168.89		No.WRD/SD I/ WD II/ F-Estt/08/2022-23. DATED: 01-04-2022.
	F.114/02/2021	5/3/2022	2/4/2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.114/03/2021						168.89		
1.2	F.114/04/2021						164.44		do
	F.114/05/2021	5/3/2022	2/4/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.114/06/2021						168.89		
2.1	F.114/07/2021						164.44		do
	F.114/08/2021	7/3/2022	4/4/2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.114/09/2021						168.89		
2.2	F.114/10/2021						168.89		do
	F.114/11/2021	7/3/2022	4/4/2022	Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	F.114/12/2021						168.89		
3.1	F.114/13/2021						168.89		do
	F.114/14/2021	8/3/2022	5/4/2022	Foundation & Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.114/15/2021						168.89		
3.2	F.114/16/2021						168.89		do
	F.114/17/2021	8/3/2022	5/4/2022	Foundation & Wall	1.2.4	100 kg/cm2	168.89	168.89	
	F.114/18/2021						168.89		
4.1	F.114/19/2021						164.44		do
	F.114/20/2021	9/3/2022	6/4/2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.114/21/2021						164.44		
4.2	F.114/22/2021						164.44		do
	F.114/23/2021	9/3/2022	6/4/2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.114/24/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection wall for nallah in Sy.No. 198 in Village Guirdolim in Cuncolim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.114/25/2021						168.89		No.WRD/SD I/ WD II/ F-Estt/08/2022-23. DATED: 01-04-2022.
	F.114/26/2021	10/3/2022	7/4/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.114/27/2021						164.44		
5.2	F.114/28/2021						164.44		
	F.114/29/2021	10/3/2022	7/4/2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	do
	F.114/30/2021						164.44		
6.1	F.114/31/2021						164.44		
	F.114/32/2021	11/3/2022	8/4/2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	do
	F.114/33/2021						164.44		
6.2	F.114/34/2021						164.44		
	F.114/35/2021	11/3/2022	8/4/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.114/36/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER