

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nallah bank at Shirwada in Sy.No. 46/4 in V.P. Shiroda in Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.118/21/2021						155.56		No. WRD/WD XI/SD IV/
	F.118/22/2021	4/4/2022	2/5/2022	Foundation	1.2.4	150 kg/cm2	151.11	155.56	F.185/16/2022-23
	F.118/23/2021						160.00		DATED:- 11-04-2022
2	F.118/24/2021						155.56		
	F.118/25/2021	5/4/2022	3/5/2022	Foundation	1.2.4	150 kg/cm2	151.11	154.08	do
	F.118/26/2021						155.56		
3	F.118/27/2021						155.56		
	F.118/28/2021	6/4/2022	4/5/2022	Foundation	1.2.4	150 kg/cm2	160.00	157.04	do
	F.118/29/2021						155.56		
4	F.118/30/2021						155.56		
	F.118/31/2021	7/4/2022	5/5/2022	Foundation	1.2.4	150 kg/cm2	151.11	152.59	do
	F.118/32/2021						151.11		
5	F.118/33/2021						155.56		
	F.118/34/2021	8/4/2022	6/5/2022	Foundation	1.2.4	150 kg/cm2	160.00	155.56	do
	F.118/35/2021						151.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER