

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Lift Irrigation scheme to provide water for plants under Biodiversity at Gautan Mopa in Pernem Taluka.

SAMPLE SENT BY: AE, SD III, WD I, WRD, Pernem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.20/06/2021						168.89		No. MI/SD III/WD I/ F.58/2021-22/377. DATED:- 07-02-2022
	F.20/07/2021	28-01-2022	25-02-2022	Protection Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.20/08/2021						168.89		
2	F.20/09/2021						168.89		do
	F.20/10/2021	28-01-2022	25-02-2022	Protection Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.20/11/2021						168.89		
3	F.20/12/2021						173.33		do
	F.20/13/2021	28-01-2022	25-02-2022	Protection Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.20/14/2021						164.44		
4	F.20/15/2021						173.33		do
	F.20/16/2021	28-01-2022	25-02-2022	Protection Wall	1.2.4	150 kg/cm2	168.89	170.37	
	F.20/17/2021						168.89		
5	F.20/18/2021						160.00		do
	F.20/19/2021	28-01-2022	25-02-2022	Protection Wall	1.2.4	150 kg/cm2	164.44	162.96	
	F.20/20/2021						164.44		
6	F.20/21/2021						164.44		do
	F.20/22/2021	29-01-2022	26-02-2022	Protection Wall	1.2.4	150 kg/cm2	164.44	164.44	
	F.20/23/2021						164.44		
7	F.20/24/2021						164.44		do
	F.20/25/2021	29-01-2022	26-02-2022	Protection Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.20/26/2021						168.89		
8	F.20/27/2021						164.44		do
	F.20/28/2021	29-01-2022	26-02-2022	Protection Wall	1.2.4	150 kg/cm2	164.44	164.44	
	F.20/29/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Lift Irrigation scheme to provide water for plants under Biodiversity at Gautan Mopa in Pernem Taluka.

SAMPLE SENT BY: AE, SD III, WD I, WRD, Pernem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9	F.20/30/2021						168.89		No. MI/SD III/WD I/ F.58/2021-22/377. DATED:- 07-02-2022
	F.20/31/2021	29-01-2022	26-02-2022	Protection Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.20/32/2021						168.89		
10	F.20/33/2021						164.44		do
	F.20/34/2021	29-01-2022	26-02-2022	Protection Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.20/35/2021						168.89		
11	F.20/36/2021						164.44		do
	F.20/37/2021	29-01-2022	26-02-2022	Protection Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.20/38/2021						168.89		
12	F.20/39/2021						168.89		do
	F.20/40/2021	30-01-2022	27-02-2022	Protection Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.20/41/2021						168.89		
13	F.20/42/2021						168.89		do
	F.20/43/2021	30-01-2022	27-02-2022	Protection Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.20/44/2021						168.89		
14	F.20/45/2021						168.89		do
	F.20/46/2021	30-01-2022	27-02-2022	Protection Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.20/47/2021						168.89		
15	F.20/48/2021						168.89		do
	F.20/49/2021	30-01-2022	27-02-2022	Protection Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.20/50/2021						168.89		
16	F.20/51/2021						168.89		do
	F.20/52/2021	31-01-2022	28-02-2022	Protection Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.20/53/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of Lift Irrigation scheme to provide water for plants under Biodiversity at Gautan Mopa in Pernem Taluka.

SAMPLE SENT BY: AE, SD III, WD I, WRD, Pernem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
17	F.20/54/2021						168.89		No. MI/SD III/WD I/ F.58/2021-22/377. DATED:- 07-02-2022
	F.20/55/2021	31-01-2022	28-02-2022	Protection Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.20/56/2021						168.89		
18	F.20/57/2021						168.89		do
	F.20/58/2021	31-01-2022	28-02-2022	Protection Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.20/59/2021						168.89		
19	F.20/60/2021						173.33		do
	F.20/61/2021	31-01-2022	28-02-2022	Protection Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.20/62/2021						164.44		
20	F.20/63/2021						231.11		do
	F.20/64/2021	1/2/2022	1/3/2022	Bandhara	1.1.5.3	200 kg/cm2	231.11	231.11	
	F.20/65/2021						231.11		
21	F.20/66/2021						240.00		do
	F.20/67/2021	1/2/2022	1/3/2022	Bandhara	1.1.5.3	200 kg/cm2	231.11	235.56	
	F.20/68/2021						235.56		
22	F.20/69/2021						231.11		do
	F.20/70/2021	1/2/2022	1/3/2022	Bandhara	1.1.5.3	200 kg/cm2	240.00	237.04	
	F.20/71/2021						240.00		
23	F.20/72/2021						240.00		do
	F.20/73/2021	1/2/2022	1/3/2022	Bandhara	1.1.5.3	200 kg/cm2	231.11	234.04	
	F.20/74/2021						231.00		
24	F.20/75/2021						164.44		do
	F.20/76/2021	3/2/2022	3/3/2022	Protection Wall	1.2.4	150 kg/cm2	168.89	165.92	
	F.20/77/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Lift Irrigation scheme to provide water for plants under Biodiversity at Gautan Mopa in Pernem Taluka.

SAMPLE SENT BY: AE, SD III, WD I, WRD, Pernem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
25	F.20/78/2021						173.33		No. MI/SD III/WD I/ F.58/2021-22/377. DATED:- 07-02-2022
	F.20/79/2021	3/2/2022	3/3/2022	Protection Wall	1.2.4	150 kg/cm2	168.89	170.37	
	F.20/80/2021						168.89		
26	F.20/81/2021						160.00		do
	F.20/82/2021	3/2/2022	3/3/2022	Protection Wall	1.2.4	150 kg/cm2	164.44	162.96	
	F.20/83/2021						164.44		
27	F.20/84/2021						164.44		do
	F.20/85/2021	3/2/2022	3/3/2022	Protection Wall	1.2.4	150 kg/cm2	164.44	164.44	
	F.20/86/2021						164.44		
28	F.20/87/2021						164.44		do
	F.20/88/2021	4/2/2022	4/3/2022	Protection Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.20/89/2021						168.89		
29	F.20/90/2021						168.89		do
	F.20/91/2021	4/2/2022	4/3/2022	Protection Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.20/92/2021						168.89		
30	F.20/93/2021						164.44		do
	F.20/94/2021	4/2/2022	4/3/2022	Protection Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.20/95/2021						168.89		
31	F.20/96/2021						164.44		do
	F.20/97/2021	4/2/2022	4/3/2022	Protection Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.20/98/2021						168.89		
32	F.20/99/2021						168.89		do
	F.20/100/2021	4/2/2022	4/3/2022	Protection Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.20/101/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER