

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization and Re-storation of collapsed portion of hill in Sy.No. 346/4 near Piedade Pinto house at Baradi in Village Velim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.127/06/2021						168.89		No.WRD/SD I/ WD II/ F.Estt/09/2022-23 DATED:- 01-04-2022
	F.127/07/2021	5/3/2022	2/4/2022	Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	F.127/08/2021						168.89		
1.2	F.127/09/2021						168.89		do
	F.127/10/2021	5/3/2022	2/4/2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.127/11/2021						168.89		
2.1	F.127/12/2021						164.44		do
	F.127/13/2021	7/3/2022	4/4/2022	Foundation	1.2.4	150 kg/cm2	168.89	165.92	
	F.127/14/2021						164.44		
2.2	F.127/15/2021						164.44		do
	F.127/16/2021	7/3/2022	4/4/2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.127/17/2021						168.89		
3.1	F.127/18/2021						160.00		do
	F.127/19/2021	8/3/2022	5/4/2022	Wall	1.2.4	150 kg/cm2	164.44	162.96	
	F.127/20/2021						164.44		
3.2	F.127/21/2021						164.44		do
	F.127/22/2021	8/3/2022	5/4/2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	
	F.127/23/2021						164.44		
4.1	F.127/24/2021						164.44		do
	F.127/25/2021	9/3/2022	6/4/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.127/26/2021						168.89		
4.2	F.127/27/2021						164.44		do
	F.127/28/2021	9/3/2022	6/4/2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	
	F.127/29/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization and Re-storage of collapsed portion of hill in Sy.No. 346/4 near Piedade Pinto house at Baradi in Village Velim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
5.1	F.127/30/2021						168.89		No.WRD/SD I/ WD II/ F.Estt/09/2022-23 DATED:- 01-04-2022
	F.127/31/2021	10/3/2022	7/4/2022	Wall	1.2.4	150 kg/cm ²	168.89	168.89	
	F.127/32/2021						168.89		
5.2	F.127/33/2021						160.00		do
	F.127/34/2021	10/3/2022	7/4/2022	Wall	1.2.4	150 kg/cm ²	168.89	165.93	
	F.127/35/2021						168.89		
6.1	F.127/36/2021						164.44		do
	F.127/37/2021	11/3/2022	8/4/2022	Wall	1.2.4	150 kg/cm ²	168.89	167.41	
	F.127/38/2021						168.89		
6.2	F.127/39/2021						168.89		do
	F.127/40/2021	11/3/2022	8/4/2022	Wall	1.2.4	150 kg/cm ²	168.89	168.89	
	F.127/41/2021						168.89		
7.1	F.127/42/2021						168.89		do
	F.127/43/2021	12/3/2022	9/4/2022	Wall	1.2.4	150 kg/cm ²	164.44	167.41	
	F.127/44/2021						168.89		
7.2	F.127/45/2021						168.89		do
	F.127/46/2021	12/3/2022	9/4/2022	Wall	1.2.4	150 kg/cm ²	168.89	168.89	
	F.127/47/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER