

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to existing Irrigation tank Dhulpe in V.P. Shiroda of Shiroda Taluka. (2nd Call).

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.130/06/2021						168.89		No.WRD/WD XI/SD IV/ WF.185/60/2022-23. <b>DATED:- 05-05-2022.</b>
	F.130/07/2021	7/4/2022	5/5/2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.130/08/2021						168.89		
1.2	F.130/09/2021						164.44		
	F.130/10/2021	7/4/2022	5/5/2022	Foundation	1.2.4	150 kg/cm2	173.33	168.89	do
	F.130/11/2021						168.89		
2.1	F.130/12/2021						164.44		
	F.130/13/2021	8/4/2022	6/5/2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	F.130/14/2021						168.89		
2.2	F.130/15/2021						168.89		
	F.130/16/2021	8/4/2022	6/5/2022	Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	F.130/17/2021						168.89		
3.1	F.130/18/2021						168.89		
	F.130/19/2021	9/4/2022	7/5/2022	Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	F.130/20/2021						168.89		
3.2	F.130/21/2021						168.89		
	F.130/22/2021	9/4/2022	7/5/2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	do
	F.130/23/2021						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**