

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to Boxechem tollem at Bamboll Dialgona in V.P. Telaulim in Navelim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.132/01/2021						168.89		No. WRD/SD I/WD II/ F.Estt/790/2021-22. DATED: 07-03-2022.
	F.132/02/2021	21-02-2022	21-03-2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.132/03/2021						168.89		
1.2	F.132/04/2021						160.00		do
	F.132/05/2021	21-02-2022	21-03-2022	Foundation	1.2.4	150 kg/cm2	168.89	165.93	
	F.132/06/2021						168.89		
2.1	F.132/07/2021						164.44		do
	F.132/08/2021	22-02-2022	22-03-2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.132/09/2021						168.89		
2.2	F.132/10/2021						168.89		do
	F.132/11/2021	22-02-2022	22-03-2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.132/12/2021						168.89		
3.1	F.132/13/2021						168.89		do
	F.132/14/2021	23-02-2022	23-03-2022	Foundation & Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.132/15/2021						168.89		
3.2	F.132/16/2021						168.89		do
	F.132/17/2021	23-02-2022	23-03-2022	Foundation & Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.132/18/2021						168.89		
4.1	F.132/19/2021						164.44		do
	F.132/20/2021	24-02-2022	24-03-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.132/21/2021						168.89		
4.2	F.132/22/2021						164.44		do
	F.132/23/2021	24-02-2022	24-03-2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	
	F.132/24/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to Boxechem tollem at Bamboll Dialgona in V.P. Telaulim in Navelim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfnd- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
5.1	F.132/25/2021						168.89		No. WRD/SD I/WD II/ F.Estt/790/2021-22. DATED: 07-03-2022.
	F.132/26/2021	25-02-2022	25-03-2022	Wall	1.2.4	150 kg/cm ²	164.44	167.41	
	F.132/27/2021						168.89		
5.2	F.132/28/2021						168.89		do
	F.132/29/2021	25-02-2022	25-03-2022	Wall	1.2.4	150 kg/cm ²	168.89	168.89	
	F.132/30/2021						168.89		
6.1	F.132/31/2021						164.44		do
	F.132/32/2021	26-02-2022	26-03-2022	Wall	1.2.4	150 kg/cm ²	168.89	165.92	
	F.132/33/2021						164.44		
6.2	F.132/34/2021						164.44		do
	F.132/35/2021	26-02-2022	26-03-2022	Wall	1.2.4	150 kg/cm ²	168.89	167.41	
	F.132/36/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER