

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of flood protection wall for the Verna Lake at Ambulor in V.P. Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.135/05/2021						168.89		No. WRD/SD I/WD II/ F.Esst/41/2022-23. DATED:- 15-04-2022
	F.135/06/2021	3/4/2022	1/5/2022	Foundation	1.2.4	150 kg/cm2	173.33	170.37	
	F.135/07/2021						168.89		
1.2	F.135/08/2021						168.89		do
	F.135/09/2021	3/4/2022	1/5/2022	Foundation	1.2.4	150 kg/cm2	173.33	171.85	
	F.135/10/2021						173.33		
1.3	F.135/11/2021						168.89		do
	F.135/12/2021	3/4/2022	1/5/2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.135/13/2021						168.89		
2.1	F.135/14/2021						168.89		do
	F.135/15/2021	4/4/2022	2/5/2022	Foundation	1.2.4	150 kg/cm2	168.89	170.37	
	F.135/16/2021						173.33		
2.2	F.135/17/2021						168.89		do
	F.135/18/2021	4/4/2022	2/5/2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.135/19/2021						168.89		
2.3	F.135/20/2021						173.33		do
	F.135/21/2021	4/4/2022	2/5/2022	Foundation	1.2.4	150 kg/cm2	173.33	171.85	
	F.135/22/2021						168.89		
3.1	F.135/23/2021						168.89		do
	F.135/24/2021	7/4/2022	5/5/2022	Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.135/25/2021						168.89		
3.2	F.135/26/2021						173.33		do
	F.135/27/2021	7/4/2022	5/5/2022	Wall	1.2.4	150 kg/cm2	164.44	167.40	
	F.135/28/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of flood protection wall for the Verna Lake at Ambulor in V.P. Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.135/29/2021						168.89		No. WRD/SD I/WD II/ F.Esst/41/2022-23. DATED:- 15-04-2022
	F.135/30/2021	8/4/2022	6/5/2022	Wall	1.2.4	150 kg/cm2	168.89	170.37	
	F.135/31/2021						173.33		
4.2	F.135/32/2021						168.89		do
	F.135/33/2021	8/4/2022	6/5/2022	Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.135/34/2021						168.89		
5.1	F.135/35/2021						168.89		
	F.135/36/2021	11/4/2022	9/5/2022	Wall	1.2.4	150 kg/cm2	168.89	170.37	
	F.135/37/2021						173.33		
5.2	F.135/38/2021						173.33		do
	F.135/39/2021	11/4/2022	9/5/2022	Wall	1.2.4	150 kg/cm2	173.33	171.85	
	F.135/40/2021						168.89		
6.1	F.135/41/2021						164.44		do
	F.135/42/2021	12/4/2022	10/5/2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.135/43/2021						168.89		
6.2	F.135/44/2021						173.33		do
	F.135/45/2021	12/4/2022	10/5/2022	Wall	1.2.4	150 kg/cm2	164.44	168.89	
	F.135/46/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER