

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of bridge across branch canal of SIP at Ghonger in ward IV of Cuncolim Muncipal area of Cuncolim Constituency.

**SAMPLE SENT BY:** AE, SD III, WD XIV, WRD, Cuncolim- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.8/05/2021						115.56		No.WRD/SD III/ WD
	F.8/06/2021	24/11/2021	1/12/2021	Foundation of culvert	1.2.4	100 kg/cm2	115.56	117.04	XIV/W.F-5/2021-22/181
	F.8/07/2021						120.00		<b>DATED: 29-11-2021.</b>
1.2	F.8/08/2021						120.00		
	F.8/09/2021	24/11/2021	1/12/2021	Foundation of culvert	1.2.4	100 kg/cm2	120.00	120.00	do
	F.8/10/2021						120.00		
2.1	F.8/11/2021						115.56		
	F.8/12/2021	26-11-2021	3/12/2021	Foundation of culvert	1.2.4	100 kg/cm2	120.00	117.04	do
	F.8/13/2021						115.56		
2.2	F.8/14/2021						115.56		
	F.8/15/2021	26-11-2021	3/12/2021	Foundation of culvert	1.2.4	100 kg/cm2	120.00	118.52	do
	F.8/16/2021						120.00		
3.1	F.8/17/2021						120.00		
	F.8/18/2021	27-11-2021	4/12/2021	Foundation of culvert	1.2.4	100 kg/cm2	115.56	117.04	do
	F.8/19/2021						115.56		
3.2	F.8/20/2021						120.00		
	F.8/21/2021	27-11-2021	4/12/2021	Foundation of culvert	1.2.4	100 kg/cm2	120.00	120.00	do
	F.8/22/2021						120.00		
4.1	F.8/23/2021						160.00		No.WRD/SD III/ WD
	F.8/24/2021	9/12/2021	16-12-2021	Slab Culvert	1.1.5.3	135 kg/cm2	155.56	158.52	XIV/W.F-5/2021-22/186
	F.8/25/2021						160.00		<b>DATED: 13-12-2021.</b>
4.2	F.8/26/2021						155.56		
	F.8/27/2021	9/12/2021	16-12-2021	Slab Culvert	1.1.5.3	135 kg/cm2	155.56	157.04	do
	F.8/28/2021						160.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**