

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement to the nallah and Construction of Retaining wall in Sy.No. 63/2-A at Poriabhat Verna in Ward No. 2 in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfnd- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.25/05/2021						115.56		No. WRD/SD I/WD II/ F.Estt/631/2021-22 DATED:- 24-12-2021
	F.25/06/2021	17-12-2021	24-12-2021	Foundation	1.2.4	100 kg/cm2	120.00	118.52	
	F.25/07/2021						120.00		
2	F.25/08/2021						115.56		do
	F.25/09/2021	18-12-2021	25-12-2021	Foundation	1.2.4	100 kg/cm2	120.00	115.56	
	F.25/10/2021						111.11		
3	F.25/11/2021						115.56		do
	F.25/12/2021	19-12-2021	26-12-2021	Foundation	1.2.4	100 kg/cm2	124.44	117.04	
	F.25/13/2021						111.11		
4	F.25/14/2021						120.00		do
	F.25/15/2021	20-12-2021	27-12-2021	Foundation	1.2.4	100 kg/cm2	120.00	117.04	
	F.25/16/2021						111.11		
5	F.25/17/2021						115.56		do
	F.25/18/2021	21-12-2021	28-12-2021	Foundation	1.2.4	100 kg/cm2	115.55	117.04	
	F.25/19/2021						120.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER