

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the existing nallah and Construction of retaining wall in Sy.No.67/7 in Seraulim Village in Benaulim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.16/01/2021						164.44		No. WRD/SD I/ WD II/
	F.16/02/2021	8/2/2022	8/3/2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	F.Esst/752/2021-22
	F.16/03/2021						164.44		DATED:- 22-02-2022.
1.2	F.16/04/2021						164.44		
	F.16/05/2021	8/2/2022	8/3/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.16/06/2021						168.89		
2.1	F.16/07/2021						164.44		
	F.16/08/2021	10/2/2022	10/3/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.16/09/2021						168.89		
2.2	F.16/10/2021						168.89		
	F.16/11/2021	10/2/2022	10/3/2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	do
	F.16/12/2021						164.44		
2.3	F.16/13/2021						164.44		
	F.16/14/2021	10/2/2022	10/3/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.16/15/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER