

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement to the pond and nallah and construction of Retaining wall in Sy.No. 84/6B, 84/6A and 111/7 in Colva Village

in Benaulim Constituency. (2nd call).

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfnd- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.17/01/2021						164.44		No. WRD/SD I/WD II/ F.Esst/762/2021-22. DATED:- 23-02-2022
	F.17/02/2021	9/2/2022	9/3/2022	Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.17/03/2021						164.44		
1.2	F.17/04/2021						168.89		do
	F.17/05/2021	9/2/2022	9/3/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.17/06/2021						164.44		
2.1	F.17/07/2021						164.44		do
	F.17/08/2021	11/2/2022	11/3/2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.17/09/2021						164.44		
2.2	F.17/10/2021						164.44		do
	F.17/11/2021	11/2/2022	11/3/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.17/12/2021						168.89		
3.1	F.17/13/2021						168.89		do
	F.17/14/2021	15-02-2022	15-03-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.17/15/2021						164.44		
3.2	F.17/16/2021						164.44		do
	F.17/17/2021	15-02-2022	15-03-2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.17/18/2021						164.44		
4	F.17/19/2021						164.44		do
	F.17/20/2021	17-02-2022	17-03-2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.17/21/2021						164.44		
5.1	F.17/22/2021						164.44		do
	F.17/23/2021	18-02-20-22	18-03-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.17/24/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the pond and nallah and construction of Retaining wall in Sy.No. 84/6B, 84/6A and 111/7 in Colva Village in Benaulim Constituency. (2nd call).

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.2	F.17/25/2021						164.44		No. WRD/SD I/WD II/ F.Esst/762/2021-22. DATED:- 23-02-2022
	F.17/26/2021	18-02-20-22	18-03-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.17/27/2021						164.44		
5.3	F.17/28/2021						164.44		do
	F.17/29/2021	18-02-20-22	18-03-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.17/30/2021						168.89		
6.1	F.17/31/2021						168.89		
	F.17/32/2021	19-02-2022	19-03-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.17/33/2021						164.44		
6.2	F.17/34/2021						164.44		do
	F.17/35/2021	19-02-2022	19-03-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.17/36/2021						164.44		
7.1	F.17/37/2021						164.44		do
	F.17/38/2021	21-02-2022	21-03-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.17/39/2021						164.44		
7.2	F.17/40/2021						164.44		do
	F.17/41/2021	21-02-2022	21-03-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.17/42/2021						168.89		
8.1	F.17/43/2021						168.89		do
	F.17/44/2021	22-02-2022	22-03-2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.17/45/2021						168.89		
7.2	F.17/40/2021						164.44		do
	F.17/41/2021	22-02-2022	22-03-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.17/42/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER