

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Protection wall for nallah in Sy.No. 130/ 23 to 130/39 in Village Mullem in Cuncolim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.23/05/2021						168.89		No. WRD/SD I/ WD II/ F.Esst/398/2021-22 <b>DATED:- 07-12-2021</b>
	F.23/06/2021	26-11-2021	24-12-2021	Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	F.23/07/2021						168.89		
2	F.23/08/2021						168.89		do
	F.23/09/2021	26-11-2021	24-12-2021	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.23/10/2021						168.89		
3	F.23/11/2021						173.33		do
	F.23/12/2021	29-11-2021	27-12-2021	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.23/13/2021						164.44		
4.1	F.23/14/2021						173.33		do
	F.23/15/2021	30-11-2021	28-12-2021	Foundation	1.2.4	150 kg/cm2	168.89	170.37	
	F.23/16/2021						168.89		
4.2	F.23/17/2021						160.00		do
	F.23/18/2021	30-11-2021	28-12-2021	Foundation	1.2.4	150 kg/cm2	164.44	162.96	
	F.23/19/2021						164.44		
5.1	F.23/20/2021						164.44		do
	F.23/21/2021	1/12/2021	29-12-2021	Wall	1.2.4	150 kg/cm2	164.44	164.44	
	F.23/22/2021						164.44		
5.2	F.23/23/2021						164.44		do
	F.23/24/2021	1/12/2021	29-12-2021	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.23/25/2021						168.89		
6.1	F.23/26/2021						164.44		do
	F.23/27/2021	3/12/2021	31-12-2021	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.23/28/2021						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Protection wall for nallah in Sy.No. 130/ 23 to 130/39 in Village Mullem in Cuncolim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.2	F.23/29/2021						168.89		No. WRD/SD I/ WD II/
	F.23/30/2021	3/12/2021	31-12-2021	Wall	1.2.4	150 kg/cm2	168.89	165.93	F.Esst/398/2021-22
	F.23/31/2021						160.00		<b>DATED:- 07-12-2021</b>
7.1	F.23/32/2021						164.44		
	F.23/33/2021	4/12/2021	1/1/2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	do
	F.23/34/2021						164.44		
7.2	F.23/35/2021						164.44		
	F.23/36/2021	4/12/2021	1/1/2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	do
	F.23/37/2021						164.44		
8.1	F.23/38/2021						164.44		
	F.23/39/2021	6/12/2021	3/1/2022	Wall	1.2.4	150 kg/cm2	168.89	165.92	do
	F.23/40/2021						164.44		
8.2	F.23/41/2021						160.00		
	F.23/42/2021	6/12/2021	3/1/2022	Wall	1.2.4	150 kg/cm2	164.44	162.96	do
	F.23/43/2021						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**