

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Protection wall to nallah in Sy.No. 235/2 at Daushire Usgao in Ponda Taluka.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.32/10/2021						80.00		No. WRD/WD XI/ SD IV/ F.410/413/2021-22. <b>DATED: 21-12-2021</b>
	F.32/11/2021	14-12-2021	21-12-2021	Foundation Ch. 0.00 m to 30.00 m	1.3.6	70 kg/cm2	75.56	77.04	
	F.32/12/2021						75.56		
1.2	F.32/13/2021						75.56		do
	F.32/14/2021	14-12-2021	21-12-2021	Foundation Ch. 0.00 m to 30.00 m	1.3.6	70 kg/cm2	75.56	74.08	
	F.32/15/2021						71.11		
2.1	F.32/16/2021						80.00		do
	F.32/17/2021	15-12-2021	22-12-2021	Foundation Ch. 30.00 m to 60.00 m	1.3.6	70 kg/cm2	75.56	78.52	
	F.32/18/2021						80.00		
2.2	F.32/19/2021						75.56		do
	F.32/20/2021	15-12-2021	22-12-2021	Foundation Ch. 30.00 m to 60.00 m	1.3.6	70 kg/cm2	80.00	78.52	
	F.32/21/2021						80.00		
3.1	F.32/22/2021						75.56		do
	F.32/23/2021	16-12-2021	23-12-2021	Foundation Ch. 60.00 m to 90.00 m	1.3.6	70 kg/cm2	75.56	74.08	
	F.32/24/2021						71.11		
3.3	F.32/25/2021						75.56		do
	F.32/26/2021	16-12-2021	23-12-2021	Foundation Ch. 60.00 m to 90.00 m	1.3.6	70 kg/cm2	71.11	74.08	
	F.32/27/2021						75.56		
4.1	F.32/28/2021						71.11		do
	F.32/29/2021	17-12-2021	24-12-2021	Foundation Ch. 90.00 m to 120.00 m	1.3.6	70 kg/cm2	75.56	75.56	
	F.32/30/2021			Above Foundation			80.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Protection wall to nallah in Sy.No. 235/2 at Daushire Usgao in Ponda Taluka.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.2	F.32/31/2021						80.00		No. WRD/WD XI/ SD IV/
	F.32/32/2021	17-12-2021	24-12-2021	Foundation Ch. 90.00 m to 120.00 m	1.3.6	70 kg/cm2	80.00	78.52	F.410/413/2021-22.
	F.32/33/2021			Above Foundation			75.56		<b>DATED: 21-12-2021</b>
5.1	F.32/34/2021						75.56		
	F.32/35/2021	18-12-2021	26-12-2021	Above Foundation	1.3.6	70 kg/cm2	80.00	77.04	do
	F.32/36/2021						75.56		
5.2	F.32/37/2021						80.00		
	F.32/38/2021	18-12-2021	26-12-2021	Above Foundation	1.3.6	70 kg/cm2	75.56	78.52	do
	F.32/39/2021						80.00		
6.1	F.32/40/2021						75.56		
	F.32/41/2021	20-12-2021	27-12-2021	Above Foundation	1.3.6	70 kg/cm2	80.00	78.52	do
	F.32/42/2021						80.00		
6.2	F.32/43/2021						75.56		
	F.32/44/2021	20-12-2021	27-12-2021	Above Foundation	1.3.6	70 kg/cm2	75.56	74.08	do
	F.32/45/2021						71.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of Protection wall to nallah in Sy.No. 235/2 at Daushire Usgao in Ponda Taluka.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
7.1	F.32/83/2021						75.56		No. WRD/WD XI/ SD IV/ F.410/472/2021-22. <b>DATED: 25-01-2022</b>
	F.32/84/2021	18-01-2022	25-01-2022	Foundation Ch. 120.00 m to 160.00 m	1.3.6	70 kg/cm2	75.56	75.56	
	F.32/85/2021						75.56		
7.2	F.32/86/2021						75.56		do
	F.32/87/2021	18-01-2022	25-01-2022	Foundation Ch. 120.00 m to 160.00 m	1.3.6	70 kg/cm2	75.56	74.08	
	F.32/88/2021						71.11		
8.1	F.32/89/2021						75.56		do
	F.32/90/2021	19-01-2022	26-01-2022	Foundation Ch. 160.00 m to 200.00 m	1.3.6	70 kg/cm2	75.56	75.56	
	F.32/91/2021			& Above Foundation			75.56		
8.2	F.32/92/2021						75.56		do
	F.32/93/2021	19-01-2022	26-01-2022	Foundation Ch. 160.00 m to 200.00 m	1.3.6	70 kg/cm2	71.11	72.59	
	F.32/94/2021			& Above Foundation			71.11		
9.1	F.32/95/2021						75.56		do
	F.32/96/2021	20-01-2022	27-01-2022	Foundation Ch. 200.00 m to 220.00 m	1.3.6	70 kg/cm2	75.56	74.08	
	F.32/97/2021			& horizontal middle belt			71.11		
9.2	F.32/98/2021						75.56		do
	F.32/99/2021	20-01-2022	27-01-2022	Foundation Ch. 200.00 m to 220.00 m	1.3.6	70 kg/cm2	71.11	74.08	
	F.32/100/2021			& horizontal middle belt			75.56		
10.1	F.32/101/2021						71.11		do
	F.32/102/2021	21-01-2022	28-01-2022	Foundation Ch. 220.00 m to 250.00 m	1.3.6	70 kg/cm2	75.56	72.59	
	F.32/103/2021			& horizontal middle belt			71.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of Protection wall to nallah in Sy.No. 235/2 at Daushire Usgao in Ponda Taluka.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
10.2	F.32/104/2021						75.56		No. WRD/WD XI/ SD IV/ F.410/472/2021-22. <b>DATED: 25-01-2022</b>
	F.32/105/2021	21-01-2022	28-01-2022	Foundation Ch. 220.00 m to 250.00 m	1.3.6	70 kg/cm2	71.11	74.08	
	F.32/106/2021			& horizontal middle belt			75.56		
11	F.32/107/2021						75.56		do
	F.32/108/2021	22-01-2022	29-01-2022	Horizontal top Belt	1.3.6	70 kg/cm2	71.11	72.59	
	F.32/109/2021						71.11		
12	F.32/110/2021						75.56		do
	F.32/111/2021	24-01-2022	31-01-2022	Horizontal top Belt	1.3.6	70 kg/cm2	75.56	74.08	
	F.32/112/2021						71.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**