

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Developemnt and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.36/06/2021						146.67		No. WRD/WD XII/SD V/
	F.36/07/2021	16-12-2021	23-12-2021	LHS Foundation	1.2.4	140 kg/cm2	151.11	151.11	F.36/137/2021-22
	F.36/08/2021						155.56		DATED:- 23-12-2021
1.2	F.36/09/2021						160.00		
	F.36/10/2021	16-12-2021	23-12-2021	LHS Foundation	1.2.4	140 kg/cm2	151.11	155.56	do
	F.36/11/2021						155.56		
2.1	F.36/12/2021						168.89		
	F.36/13/2021	17-12-2021	24-12-2021	LHs Foundation	1.2.4	140 kg/cm2	151.11	154.07	do
	F.36/14/2021			LHS 1st Lift			142.22		
2.2	F.36/15/2021						160.00		
	F.36/16/2021	17-12-2021	24-12-2021	LHs Foundation	1.2.4	140 kg/cm2	155.56	157.04	do
	F.36/17/2021			LHS 1st Lift			155.56		
3.1	F.36/18/2021						160.00		
	F.36/19/2021	18-12-2021	25-12-2021	LHS 1st Lift	1.2.4	140 kg/cm2	155.56	155.56	do
	F.36/20/2021						151.11		
3.2	F.36/21/2021						168.89		
	F.36/22/2021	18-12-2021	25-12-2021	LHS 1st Lift	1.2.4	140 kg/cm2	146.67	154.08	do
	F.36/23/2021						146.67		
4.1	F.36/24/2021						160.00		
	F.36/25/2021	20-12-2021	27-12-2021	LHS 1st Lift	1.2.4	140 kg/cm2	160.00	154.07	do
	F.36/26/2021						142.22		
4.2	F.36/27/2021						160.00		
	F.36/28/2021	20-12-2021	27-12-2021	LHS 1st Lift	1.2.4	140 kg/cm2	146.67	158.52	do
	F.36/29/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Developemnt and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.36/30/2021						168.89		No. WRD/WD XII/SD V/
	F.36/31/2021	21-12-2021	28-12-2021	LHS 1st Lift & LHS 2nd Lift	1.2.4	140 kg/cm2	151.11	154.07	F.36/137/2021-22
	F.36/32/2021						142.22		DATED:- 23-12-2021
5.2	F.36/33/2021						160.00		
	F.36/34/2021	21-12-2021	28-12-2021	LHS 1st Lift & LHS 2nd Lift	1.2.4	140 kg/cm2	155.56	157.04	do
	F.36/35/2021						155.56		
6.1	F.36/36/2021						160.00		
	F.36/37/2021	22-12-2021	29-12-2021	LHS 2nd Lift	1.2.4	140 kg/cm2	155.56	155.56	do
	F.36/38/2021						151.11		
6.2	F.36/39/2021						168.89		
	F.36/40/2021	22-12-2021	29-12-2021	LHS 2nd Lift	1.2.4	140 kg/cm2	146.67	154.08	do
	F.36/41/2021						146.67		
7.1	F.36/90/2021						160.00		No. WRD/WD XII/SD V/
	F.36/91/2021	27-12-2021	3/1/2022	RHS 1st Lift	1.2.4	140 kg/cm2	160.00	155.56	F.36/145/2021-22
	F.36/92/2021						146.67		DATED:- 01-01-2022
7.2	F.36/93/2021						146.67		
	F.36/94/2021	27-12-2021	3/1/2022	RHS 1st Lift	1.2.4	140 kg/cm2	146.67	154.08	do
	F.36/95/2021						168.89		
8.1	F.36/96/2021						160.00		
	F.36/97/2021	28-12-2021	4/1/2022	RHS 2nd Lift	1.2.4	140 kg/cm2	146.67	155.56	do
	F.36/98/2021						160.00		
8.2	F.36/99/2021						146.67		
	F.36/100/2021	28-12-2021	4/1/2022	RHS 2nd Lift	1.2.4	140 kg/cm2	155.56	154.08	do
	F.36/101/2021						160.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Developemnt and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
8.3	F.36/102/2021						160.00		No. WRD/WD XII/SD V/
	F.36/103/2021	28-12-2021	4/1/2022	RHS 2nd Lift	1.2.4	140 kg/cm2	146.67	155.56	F.36/145/2021-22
	F.36/104/2021						160.00		DATED:- 01-01-2022
8.4	F.36/105/2021						146.67		
	F.36/106/2021	28-12-2021	4/1/2022	RHS 2nd Lift	1.2.4	140 kg/cm2	155.56	154.08	do
	F.36/107/2021						160.00		
9.1	F.36/108/2021						160.00		
	F.36/109/2021	29-12-2021	5/1/2022	RHS 3rd Lift	1.2.4	140 kg/cm2	155.56	155.56	do
	F.36/110/2021						151.11		
9.2	F.36/111/2021						168.89		
	F.36/112/2021	29-12-2021	5/1/2022	RHS 3rd Lift	1.2.4	140 kg/cm2	146.67	154.08	do
	F.36/113/2021						146.67		
10	F.36/114/2021						160.00		
	F.36/115/2021	30-12-2021	6/1/2022	RHS 4th Lift	1.2.4	140 kg/cm2	160.00	154.07	do
	F.36/116/2021						142.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Developemnt and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
11.1	F.36/180/2021						146.67		No. WRD/WD XII/SD V/ F.36/164/2021-22 DATED:- 25-01-2022
	F.36/181/2021	18-01-2022	25-01-2022	RHS Foundation	1.2.4	140 kg/cm2	155.56	154.08	
	F.36/182/2021						160.00		
11.2	F.36/183/2021						146.67		do
	F.36/184/2021	18-01-2022	25-01-2022	RHS Foundation	1.2.4	140 kg/cm2	151.11	151.11	
	F.36/185/2021						155.56		
11.3	F.36/186/2021						160.00		do
	F.36/187/2021	18-01-2022	25-01-2022	RHS Foundation	1.2.4	140 kg/cm2	151.11	155.56	
	F.36/188/2021						155.56		
11.4	F.36/189/2021						168.89		do
	F.36/190/2021	18-01-2022	25-01-2022	RHS Foundation	1.2.4	140 kg/cm2	151.11	154.07	
	F.36/191/2021						142.22		
12.1	F.36/192/2021						160.00		do
	F.36/193/2021	19-01-2022	26-01-2022	RHS Foundation & LHS Foundation	1.2.4	140 kg/cm2	155.56	157.04	
	F.36/194/2021						155.56		
12.2	F.36/195/2021						160.00		do
	F.36/196/2021	19-01-2022	26-01-2022	RHS Foundation & LHS Foundation	1.2.4	140 kg/cm2	155.56	155.56	
	F.36/197/2021						151.11		
13.1	F.36/198/2021						168.89		do
	F.36/199/2021	20-01-2022	27-01-2022	RHS 1st Lift	1.2.4	140 kg/cm2	146.67	154.08	
	F.36/200/2021						146.67		
13.2	F.36/201/2021						160.00		do
	F.36/202/2021	20-01-2022	27-01-2022	RHS 1st Lift	1.2.4	140 kg/cm2	155.56	157.04	
	F.36/203/2021						155.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Developemnt and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
13.3	F.36/204/2021						160.00		No. WRD/WD XII/SD V/ F.36/164/2021-22 DATED:- 25-01-2022
	F.36/205/2021	20-01-2022	27-01-2022	RHS 1st Lift	1.2.4	140 kg/cm2	146.67	155.56	
	F.36/206/2021						160.00		
13.4	F.36/207/2021						146.67		do
	F.36/208/2021	20-01-2022	27-01-2022	RHS 1st Lift	1.2.4	140 kg/cm2	155.56	154.08	
	F.36/209/2021						160.00		
14.1	F.36/210/2021						160.00		do
	F.36/211/2021	21-01-2022	28-01-2022	RHS 1st Lift & LHS 1st Lift	1.2.4	140 kg/cm2	155.56	155.56	
	F.36/212/2021						151.11		
14.2	F.36/213/2021						160.00		do
	F.36/214/2021	21-01-2022	28-01-2022	RHS 1st Lift & LHS 1st Lift	1.2.4	140 kg/cm2	146.67	151.11	
	F.36/215/2021						146.67		
14.3	F.36/216/2021						160.00		do
	F.36/217/2021	21-01-2022	28-01-2022	RHS 1st Lift & LHS 1st Lift	1.2.4	140 kg/cm2	160.00	155.56	
	F.36/218/2021						146.67		
14.4	F.36/219/2021						168.89		do
	F.36/220/2021	21-01-2022	28-01-2022	RHS 1st Lift & LHS 1st Lift	1.2.4	140 kg/cm2	146.67	154.08	
	F.36/221/2021						146.67		
15.1	F.36/222/2021						160.00		do
	F.36/223/2021	22-01-2022	29-01-2022	RHS 2nd Lift & LHS 2nd Lift	1.2.4	140 kg/cm2	160.00	154.07	
	F.36/224/2021						142.22		
15.2	F.36/225/2021						146.67		do
	F.36/226/2021	22-01-2022	29-01-2022	RHS 2nd Lift & LHS 2nd Lift	1.2.4	140 kg/cm2	160.00	151.11	
	F.36/227/2021						146.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Developemnt and Stabilization of nallah banks at Vodlemol in Cacora Village in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
15.3	F.36/228/2021						146.67		No. WRD/WD XII/SD V/
	F.36/229/2021	22-01-2022	29-01-2022	RHS 2nd Lift & LHS 2nd Lift	1.2.4	140 kg/cm2	160.00	151.11	F.36/164/2021-22
	F.36/230/2021						146.67		DATED:- 25-01-2022
15.4	F.36/231/2021						160.00		
	F.36/232/2021	22-01-2022	29-01-2022	RHS 2nd Lift & LHS 2nd Lift	1.2.4	140 kg/cm2	160.00	155.56	do
	F.36/233/2021						146.67		
16.1	F.36/234/2021						168.89		
	F.36/235/2021	24-01-2022	31-01-2022	RHS 3rd Lift & LHS 3rd Lift	1.2.4	140 kg/cm2	146.67	154.08	do
	F.36/236/2021						146.67		
16.2	F.36/237/2021						160.00		
	F.36/238/2021	24-01-2022	31-01-2022	RHS 3rd Lift & LHS 3rd Lift	1.2.4	140 kg/cm2	160.00	154.07	do
	F.36/239/2021						142.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

