

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement and Covering of nallah near Renuka Mandir Aquem Margao- Goa.

**SAMPLE SENT BY:** AE, SD III, WD III, WRD, Gogol- Margao- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
1	F.41/05/2021						173.33		No.286/SD III/WDIII/
	F.41/06/2021	18-12-2021	15-01-2022	Side wall of the drain	1.2.4	150 kg/cm <sup>2</sup>	182.22	177.78	WRD/2021-22/385.
	F.41/07/2021						177.78		<b>DATED: 21-12-2021.</b>

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**