

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement and Covering of existing nallah near Lala house at Aquem Margao- Goa.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	F.42/05/2021						173.33		No.287/SD III/WDIII/ WRD/2021-22/384. DATED: 21-12-2021.
	F.42/06/2021	18-12-2021	15-01-2022	Foundation of the drain	1.2.4	150 kg/cm ²	182.22	177.78	
	F.42/07/2021						177.78		
2	F.42/08/2021						164.44		do
	F.42/09/2021	20-12-2021	17-01-2022	Side walls of the drain	1.2.4	150 kg/cm ²	186.67	180.74	
	F.42/10/2021						191.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER