

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Protection wall adjacent to Tarakunj Society at Murida within the jurisdiction of Margao Municipal Council.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.49/05/2021						164.44		No. 291/SD III/ WD III/ WRD/2021-22/442. DATED:- 14-01-2022
	F.49/06/2021	7/1/2022	4/2/2022	Wall Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.49/07/2021						164.44		
1.2	F.49/08/2021						168.89		do
	F.49/09/2021	7/1/2022	4/2/2022	Wall Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.49/10/2021						164.44		
2.1	F.49/11/2021						164.44		do
	F.49/12/2021	8/1/2022	5/2/2022	Wall Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.49/13/2021						164.44		
2.2	F.49/14/2021						164.44		do
	F.49/15/2021	8/1/2022	5/2/2022	Wall Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.49/16/2021						168.89		
3.1	F.49/17/2021						168.89		do
	F.49/18/2021	9/1/2022	6/2/2022	1st Lift of Wall Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.49/19/2021						164.44		
3.2	F.49/20/2021						164.44		do
	F.49/21/2021	9/1/2022	6/2/2022	1st Lift of Wall Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.49/22/2021						164.44		
3.3	F.49/23/2021						164.44		do
	F.49/24/2021	9/1/2022	6/2/2022	1st Lift of Wall Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.49/25/2021						164.44		
3.4	F.49/26/2021						164.44		do
	F.49/27/2021	9/1/2022	6/2/2022	1st Lift of Wall Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.49/28/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Protection wall adjacent to Tarakunj Society at Murida within the jurisdiction of Margao Municipal Council.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.49/29/2021						164.44		No. 291/SD III/ WD III/ WRD/2021-22/442. DATED:- 14-01-2022
	F.49/30/2021	10/1/2022	7/2/2022	2nd Lift of Wall Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.49/31/2021						164.44		
4.2	F.49/32/2021						164.44		do
	F.49/33/2021	10/1/2022	7/2/2022	2nd Lift of Wall Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.49/34/2021						168.89		
4.3	F.49/35/2021						168.89		do
	F.49/36/2021	10/1/2022	7/2/2022	2nd Lift of Wall Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.49/37/2021						164.44		
4.4	F.49/38/2021						164.44		do
	F.49/39/2021	10/1/2022	7/2/2022	2nd Lift of Wall Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.49/40/2021						164.44		
5.1	F.49/41/2021						164.44		do
	F.49/42/2021	11/1/2022	8/2/2022	3rd Lift of Wall Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.49/43/2021						164.44		
5.2	F.49/44/2021						164.44		do
	F.49/45/2021	11/1/2022	8/2/2022	3rd Lift of Wall Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.49/46/2021						168.89		
6.1	F.49/47/2021						168.89		do
	F.49/48/2021	12/1/2022	9/2/2022	3rd Lift of Wall Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	F.49/49/2021						168.89		
6.2	F.49/50/2021						168.89		do
	F.49/51/2021	12/1/2022	9/2/2022	3rd Lift of Wall Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.49/52/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER