

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization and Re-storage of collapsed portion of hill in Sy.No. 346/4 near Catarina Pinto house at Baradi in Village Velim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.51/06/2021						168.89		No.WRD/SD I/ WD II/ F.Estt/822/2021-22. DATED:- 17-03-2022
	F.51/07/2021	18-02-2022	18-03-2022	Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	F.51/08/2021						168.89		
1.2	F.51/09/2021						168.89		do
	F.51/10/2021	18-02-2022	18-03-2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.51/11/2021						168.89		
2.1	F.51/12/2021						231.11		do
	F.51/13/2021	19-02-2022	19-03-2022	Foundation	1.1.5.3	200 kg/cm2	231.11	231.11	
	F.51/14/2021						231.11		
2.2	F.51/15/2021						240.00		do
	F.51/16/2021	19-02-2022	19-03-2022	Foundation	1.1.5.3	200 kg/cm2	231.11	235.56	
	F.51/17/2021						235.56		
3.1	F.51/18/2021						244.44		do
	F.51/19/2021	21-02-2022	21-03-2022	Foundation	1.1.5.3	200 kg/cm2	240.00	238.52	
	F.51/20/2021						231.11		
3.2	F.51/21/2021						240.00		do
	F.51/22/2021	21-02-2022	21-03-2022	Foundation	1.1.5.3	200 kg/cm2	231.11	235.56	
	F.51/23/2021						235.56		
4.1	F.51/24/2021						240.00		do
	F.51/25/2021	22-02-2022	22-03-2022	Wall	1.1.5.3	200 kg/cm2	235.56	237.04	
	F.51/26/2021						235.56		
4.2	F.51/27/2021						244.44		do
	F.51/28/2021	22-02-2022	22-03-2022	Wall	1.1.5.3	200 kg/cm2	240.00	238.52	
	F.51/29/2021						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization and Re-storation of collapsed portion of hill in Sy.No. 346/4 near Catarina Pinto house at Baradi in Village Velim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
5.1	F.51/30/2021						235.56		No.WRD/SD I/ WD II/
	F.51/31/2021	23-02-2022	23-03-2022	Wall	1.1.5.3	200 kg/cm ²	231.11	234.08	F.Estt/822/2021-22.
	F.51/32/2021						235.56		DATED:- 17-03-2022
5.2	F.51/33/2021						235.56		
	F.51/34/2021	23-02-2022	23-03-2022	Wall	1.1.5.3	200 kg/cm ²	231.11	232.59	do
	F.51/35/2021						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER