

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement to existing Irrigation tank at Khedem- Priol in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda - Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.28/10/2021						164.44		No. WRD/WD XI/SD IV/ F.CF/473/2021-22 DATED:- 25-01-2022.
	F.28/11/2021	4/1/2022	1/2/2022	For Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.28/12/2021						164.44		
1.2	F.28/13/2021						164.44		do
	F.28/14/2021	4/1/2022	1/2/2022	For Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.28/15/2021						168.89		
2.1	F.28/16/2021						164.44		do
	F.28/17/2021	5/1/2022	2/2/2022	For Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.28/18/2021						168.89		
2.2	F.28/19/2021						168.89		do
	F.28/20/2021	5/1/2022	2/2/2022	For Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.28/21/2021						164.44		
3.1	F.28/22/2021						164.44		do
	F.28/23/2021	7/1/2022	4/2/2022	For Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.28/24/2021						168.89		
3.2	F.28/25/2021						168.89		do
	F.28/26/2021	7/1/2022	4/2/2022	For Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.28/27/2021						164.44		
4.1	F.28/28/2021						168.89		do
	F.28/29/2021	8/1/2022	5/2/2022	For Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.28/30/2021						164.44		
4.2	F.28/31/2021						168.89		do
	F.28/32/2021	8/1/2022	5/2/2022	For Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.28/33/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER