

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of protection wall on upstream side of tank (Kadevi Tollem) at Xeldem in V.P. Assolda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.63/06/2021						213.33		No. WRD/WD XII/SD V/ F.63/163/2021-22 DATED: 25-01-2022
	F.63/07/2021	14-01-2022	11/2/2022	Bottom Foundation	1.2.4	210 kg/cm2	217.78	214.81	
	F.63/08/2021						213.33		
1.2	F.63/09/2021						217.78		
	F.63/10/2021	14-01-2022	11/2/2022	Bottom Foundation	1.2.4	210 kg/cm2	217.78	216.30	do
	F.63/11/2021						213.33		
1.3	F.63/12/2021						213.33		
	F.63/13/2021	14-01-2022	11/2/2022	Bottom Foundation	1.2.4	210 kg/cm2	213.33	214.81	do
	F.63/14/2021						217.78		
1.4	F.63/15/2021						217.78		
	F.63/16/2021	14-01-2022	11/2/2022	Bottom Foundation	1.2.4	210 kg/cm2	217.78	214.82	do
	F.63/17/2021						208.89		
2.1	F.63/18/2021						208.89		
	F.63/19/2021	15-01-2022	12/2/2022	Bottom Foundation	1.2.4	210 kg/cm2	213.33	213.33	do
	F.63/20/2021						217.78		
2.2	F.63/21/2021						213.33		
	F.63/22/2021	15-01-2022	12/2/2022	Bottom Foundation	1.2.4	210 kg/cm2	213.33	214.81	do
	F.63/23/2021						217.78		
2.3	F.63/24/2021						208.89		
	F.63/25/2021	15-01-2022	12/2/2022	Bottom Foundation	1.2.4	210 kg/cm2	213.33	213.33	do
	F.63/26/2021						217.78		
2.4	F.63/27/2021						208.89		
	F.63/28/2021	15-01-2022	12/2/2022	Bottom Foundation	1.2.4	210 kg/cm2	217.78	213.33	do
	F.63/29/2021						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall on upstream side of tank (Kadevi Tollem) at Xeldem in V.P. Assolda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.63/30/2021						217.78		No. WRD/WD XII/SD V/ F.63/163/2021-22 DATED: 25-01-2022
	F.63/31/2021	17-01-2022	14-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	217.78	
	F.63/32/2021						217.78		
3.2	F.63/33/2021						217.78		
	F.63/34/2021	17-01-2022	14-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	213.33	do
	F.63/35/2021						208.89		
3.3	F.63/36/2021						213.33		
	F.63/37/2021	17-01-2022	14-02-2022	Foundation	1.2.4	210 kg/cm2	208.89	213.33	do
	F.63/38/2021						217.78		
3.4	F.63/39/2021						217.78		
	F.63/40/2021	17-01-2022	14-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	216.30	do
	F.63/41/2021						213.33		
3.5	F.63/42/2021						213.33		
	F.63/43/2021	17-01-2022	14-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	213.33	do
	F.63/44/2021						213.33		
3.6	F.63/45/2021						213.33		
	F.63/46/2021	17-01-2022	14-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	214.81	do
	F.63/47/2021						213.33		
3.7	F.63/48/2021						213.33		
	F.63/49/2021	17-01-2022	14-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	214.81	do
	F.63/50/2021						213.33		
3.8	F.63/51/2021						217.78		
	F.63/52/2021	17-01-2022	14-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	213.33	do
	F.63/53/2021						208.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall on upstream side of tank (Kadevi Tollem) at Xeldem in V.P. Assolda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.63/54/2021						213.33		No. WRD/WD XII/SD V/ F.63/163/2021-22 DATED: 25-01-2022
	F.63/55/2021	18-01-2022	15-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.63/56/2021						217.78		
4.2	F.63/57/2021						213.33		do
	F.63/58/2021	18-01-2022	15-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	214.81	
	F.63/59/2021						213.33		
4.3	F.63/60/2021						222.22		do
	F.63/61/2021	18-01-2022	15-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	216.29	
	F.63/62/2021						213.33		
4.4	F.63/63/2021						213.33		do
	F.63/64/2021	18-01-2022	15-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	214.81	
	F.63/65/2021						213.33		
4.5	F.63/66/2021						217.78		do
	F.63/67/2021	18-01-2022	15-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	216.30	
	F.63/68/2021						213.33		
4.6	F.63/69/2021						213.33		do
	F.63/70/2021	18-01-2022	15-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.63/71/2021						217.78		
4.7	F.63/72/2021						213.33		do
	F.63/73/2021	18-01-2022	15-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	214.81	
	F.63/74/2021						213.33		
4.8	F.63/75/2021						217.78		do
	F.63/76/2021	18-01-2022	15-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	216.30	
	F.63/77/2021						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall on upstream side of tank (Kadevi Tollem) at Xeldem in V.P. Assolda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.63/78/2021						217.78		No. WRD/WD XII/SD V/ F.63/163/2021-22 DATED: 25-01-2022
	F.63/79/2021	19-01-2022	16-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	216.30	
	F.63/80/2021						213.33		
5.2	F.63/81/2021						217.78		do
	F.63/82/2021	19-01-2022	16-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.63/83/2021						213.33		
5.3	F.63/84/2021						213.33		do
	F.63/85/2021	19-01-2022	16-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.63/86/2021						217.78		
5.4	F.63/87/2021						213.33		do
	F.63/88/2021	19-01-2022	16-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	214.81	
	F.63/89/2021						213.33		
5.5	F.63/90/2021						208.89		do
	F.63/91/2021	19-01-2022	16-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	213.33	
	F.63/92/2021						217.78		
5.6	F.63/93/2021						217.78		do
	F.63/94/2021	19-01-2022	16-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.63/95/2021						213.33		
5.7	F.63/96/2021						208.89		do
	F.63/97/2021	19-01-2022	16-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	213.33	
	F.63/98/2021						217.78		
5.8	F.63/99/2021						213.33		do
	F.63/100/2021	19-01-2022	16-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	213.33	
	F.63/101/2021						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall on upstream side of tank (Kadevi Tollem) at Xeldem in V.P. Assolda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.1	F.63/102/2021						217.78		No. WRD/WD XII/SD V/ F.63/163/2021-22 DATED: 25-01-2022
	F.63/103/2021	20-01-2022	17-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	216.30	
	F.63/104/2021						213.33		
6.2	F.63/105/2021						213.33		do
	F.63/106/2021	20-01-2022	17-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.63/107/2021						217.78		
6.3	F.63/108/2021						217.78		do
	F.63/109/2021	20-01-2022	17-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	214.82	
	F.63/110/2021						208.89		
6.4	F.63/111/2021						208.89		do
	F.63/112/2021	20-01-2022	17-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	213.33	
	F.63/113/2021						217.78		
6.5	F.63/114/2021						213.33		do
	F.63/115/2021	20-01-2022	17-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	214.81	
	F.63/116/2021						217.78		
6.6	F.63/117/2021						208.89		do
	F.63/118/2021	20-01-2022	17-02-2022	Foundation	1.2.4	210 kg/cm2	213.33	213.33	
	F.63/119/2021						217.78		
6.7	F.63/120/2021						213.33		do
	F.63/121/2022	20-01-2022	17-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	214.81	
	F.63/122/2022						213.33		
6.8	F.63/123/2021						217.78		do
	F.63/124/2021	20-01-2022	17-02-2022	Foundation	1.2.4	210 kg/cm2	217.78	216.30	
	F.63/125/2021						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall on upstream side of tank (Kadevi Tollem) at Xeldem in V.P. Assolda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
7.1	F.63/126/2021						213.33		No. WRD/WD XII/SD V/ F.63/163/2021-22 DATED: 25-01-2022
	F.63/127/2021	21-01-2022	18-02-2022	1st Lift	1.2.4	210 kg/cm2	213.33	214.81	
	F.63/128/2021						217.78		
7.2	F.63/129/2021						222.22		do
	F.63/130/2021	21-01-2022	18-02-2022	1st Lift	1.2.4	210 kg/cm2	213.33	217.78	
	F.63/131/2021						217.78		
7.3	F.63/132/2021						213.33		do
	F.63/133/2021	21-01-2022	18-02-2022	1st Lift	1.2.4	210 kg/cm2	217.78	214.81	
	F.63/134/2021						213.33		
7.4	F.63/135/2021						217.78		do
	F.63/136/2021	21-01-2022	18-02-2022	1st Lift	1.2.4	210 kg/cm2	217.78	216.30	
	F.63/137/2021						213.33		
7.5	F.63/138/2021						217.78		do
	F.63/139/2021	21-01-2022	18-02-2022	1st Lift	1.2.4	210 kg/cm2	213.33	216.30	
	F.63/140/2021						217.78		
7.6	F.63/141/2021						213.33		do
	F.63/142/2021	21-01-2022	18-02-2022	1st Lift	1.2.4	210 kg/cm2	217.78	216.30	
	F.63/143/2021						217.78		
7.7	F.63/144/2021						213.33		do
	F.63/145/2021	21-01-2022	18-02-2022	1st Lift	1.2.4	210 kg/cm2	217.78	217.78	
	F.63/146/2021						222.22		
7.8	F.63/147/2021						222.22		do
	F.63/148/2021	21-01-2022	18-02-2022	1st Lift	1.2.4	210 kg/cm2	222.22	219.26	
	F.63/149/2021						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall on upstream side of tank (Kadevi Tollem) at Xeldem in V.P. Assolda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
8.1	F.63/150/2021						222.22		No. WRD/WD XII/SD V/ F.63/163/2021-22 DATED: 25-01-2022
	F.63/151/2021	22-01-2022	19-02-2022	1st Lift	1.2.4	210 kg/cm ²	213.33	217.78	
	F.63/152/2021						217.78		
8.2	F.63/153/2021						213.33		do
	F.63/154/2021	22-01-2022	19-02-2022	1st Lift	1.2.4	210 kg/cm ²	217.78	214.81	
	F.63/155/2021						213.33		
8.3	F.63/156/2021						217.78		do
	F.63/157/2021	22-01-2022	19-02-2022	1st Lift	1.2.4	210 kg/cm ²	217.78	216.30	
	F.63/158/2021						213.33		
8.4	F.63/159/2021						217.78		do
	F.63/160/2021	22-01-2022	19-02-2022	1st Lift	1.2.4	210 kg/cm ²	213.33	216.30	
	F.63/161/2021						217.78		
8.5	F.63/162/2021						213.33		do
	F.63/163/2021	22-01-2022	19-02-2022	1st Lift	1.2.4	210 kg/cm ²	217.78	216.30	
	F.63/164/2021						217.78		
8.6	F.63/165/2021						213.33		do
	F.63/166/2021	22-01-2022	19-02-2022	1st Lift	1.2.4	210 kg/cm ²	217.78	217.78	
	F.63/167/2021						222.22		
8.7	F.63/168/2021						222.22		do
	F.63/169/2021	22-01-2022	19-02-2022	1st Lift	1.2.4	210 kg/cm ²	222.22	219.26	
	F.63/170/2021						213.33		
8.8	F.63/171/2021						222.22		do
	F.63/172/2021	22-01-2022	19-02-2022	1st Lift	1.2.4	210 kg/cm ²	226.67	220.74	
	F.63/173/2021						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall on upstream side of tank (Kadevi Tollem) at Xeldem in V.P. Assolda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
9.1	F.63/174/2021						217.78		No. WRD/WD XII/SD V/ F.63/163/2021-22 DATED: 25-01-2022
	F.63/175/2021	24-01-2022	21-02-2022	1st Lift	1.2.4	210 kg/cm ²	217.78	216.30	
	F.63/176/2021						213.33		
9.2	F.63/177/2021						217.78		do
	F.63/178/2021	24-01-2022	21-02-2022	1st Lift	1.2.4	210 kg/cm ²	213.33	216.30	
	F.63/179/2021						217.78		
9.3	F.63/180/2021						213.33		do
	F.63/181/2021	24-01-2022	21-02-2022	1st Lift	1.2.4	210 kg/cm ²	217.78	216.30	
	F.63/182/2021						217.78		
9.4	F.63/183/2021						213.33		do
	F.63/184/2021	24-01-2022	21-02-2022	1st Lift	1.2.4	210 kg/cm ²	217.78	217.78	
	F.63/185/2021						222.22		
9.5	F.63/186/2021						222.22		do
	F.63/187/2021	24-01-2022	21-02-2022	1st Lift	1.2.4	210 kg/cm ²	222.22	219.26	
	F.63/188/2021						213.33		
9.6	F.63/189/2021						222.22		do
	F.63/190/2021	24-01-2022	21-02-2022	1st Lift	1.2.4	210 kg/cm ²	226.67	220.74	
	F.63/191/2021						213.33		
9.7	F.63/192/2021						213.33		do
	F.63/193/2021	24-01-2022	21-02-2022	1st Lift	1.2.4	210 kg/cm ²	217.78	217.78	
	F.63/194/2021						222.22		
9.8	F.63/195/2021						222.22		do
	F.63/196/2021	24-01-2022	21-02-2022	1st Lift	1.2.4	210 kg/cm ²	222.22	219.26	
	F.63/197/2021						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall on upstream side of tank (Kadevi Tollem) at Xeldem in V.P. Assolda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
10.1	F.63/198/2021						213.33		No. WRD/WD XII/SD V/ F.63/184/2021-22 DATED: 23-02-2022
	F.63/199/2021	28-01-2022	25-02-2022	Middle band	1.2.4	210 kg/cm2	217.78	217.78	
	F.63/200/2021						222.22		
10.2	F.63/201/2021						222.22		do
	F.63/202/2021	28-01-2022	25-02-2022	Middle band	1.2.4	210 kg/cm2	222.22	219.26	
	F.63/203/2021						213.33		
10.3	F.63/204/2021						222.22		do
	F.63/205/2021	28-01-2022	25-02-2022	Middle band	1.2.4	210 kg/cm2	213.33	217.78	
	F.63/206/2021						217.78		
10.4	F.63/207/2021						213.33		do
	F.63/208/2021	28-01-2022	25-02-2022	Middle band	1.2.4	210 kg/cm2	217.78	214.81	
	F.63/209/2021						213.33		
11.1	F.63/210/2021						217.78		do
	F.63/211/2021	31-01-2022	28-02-2022	Top band	1.2.4	210 kg/cm2	217.78	216.30	
	F.63/212/2021						213.33		
11.2	F.63/213/2021						217.78		do
	F.63/214/2021	31-01-2022	28-02-2022	Top band	1.2.4	210 kg/cm2	222.22	219.26	
	F.63/215/2021						217.78		
12.1	F.63/216/2021						213.33		do
	F.63/217/2022	1/2/2022	1/3/2022	Foundation	1.2.4	210 kg/cm2	217.78	216.30	
	F.63/218/2022						217.78		
12.2	F.63/219/2022						217.78		do
	F.63/220/2023	1/2/2022	1/3/2022	Foundation	1.2.4	210 kg/cm2	217.78	217.78	
	F.63/221/2023						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall on upstream side of tank (Kadevi Tollem) at Xeldem in V.P. Assolda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
13.1	F.63/222/2021						217.78		No. WRD/WD XII/SD V/ F.63/184/2021-22 DATED: 23-02-2022
	F.63/223/2021	2/2/2022	2/3/2022	Bottom Foundation	1.2.4	210 kg/cm2	217.78	216.30	
	F.63/224/2021						213.33		
13.2	F.63/225/2021						217.78		do
	F.63/226/2021	2/2/2022	2/3/2022	Bottom Foundation	1.2.4	210 kg/cm2	213.33	216.30	
	F.63/227/2021						217.78		
14.1	F.63/228/2021						213.33		do
	F.63/229/2021	4/2/2022	4/3/2022	Foundation	1.2.4	210 kg/cm2	217.78	216.30	
	F.63/230/2021						217.78		
14.2	F.63/231/2021						213.33		do
	F.63/232/2021	4/2/2022	4/3/2022	Foundation	1.2.4	210 kg/cm2	217.78	217.78	
	F.63/233/2021						222.22		
14.3	F.63/234/2021						222.22		do
	F.63/235/2021	4/2/2022	4/3/2022	Foundation	1.2.4	210 kg/cm2	222.22	219.26	
	F.63/236/2021						213.33		
14.4	F.63/237/2021						222.22		do
	F.63/238/2021	4/2/2022	4/3/2022	Foundation	1.2.4	210 kg/cm2	226.67	220.74	
	F.63/239/2021						213.33		
14.5	F.63/240/2021						213.33		do
	F.63/241/2021	4/2/2022	4/3/2022	Foundation	1.2.4	210 kg/cm2	217.78	217.78	
	F.63/242/2021						222.22		
14.6	F.63/243/2021						222.22		do
	F.63/244/2021	4/2/2022	4/3/2022	Foundation	1.2.4	210 kg/cm2	222.22	219.26	
	F.63/245/2021						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of protection wall on upstream side of tank (Kadevi Tollem) at Xeldem in V.P. Assolda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
14.7	F.63/246/2021						226.67		No. WRD/WD XII/SD V/ F.63/184/2021-22 DATED: 23-02-2022
	F.63/247/2021	4/2/2022	4/3/2022	Foundation	1.2.4	210 kg/cm2	213.33	217.78	
	F.63/248/2021						213.33		
14.8	F.63/249/2021						222.22		do
	F.63/250/2021	4/2/2022	4/3/2022	Foundation	1.2.4	210 kg/cm2	217.78	217.78	
	F.63/251/2021						213.33		
15.1	F.63/252/2021						226.67		do
	F.63/253/2021	5/2/2022	5/3/2022	Foundation	1.2.4	210 kg/cm2	222.22	220.74	
	F.63/254/2021						213.33		
15.2	F.63/255/2021						213.33		do
	F.63/256/2021	5/2/2022	5/3/2022	Foundation	1.2.4	210 kg/cm2	217.78	216.30	
	F.63/257/2021						217.78		
15.3	F.63/258/2021						222.22		do
	F.63/259/2021	5/2/2022	5/3/2022	Foundation	1.2.4	210 kg/cm2	217.78	217.78	
	F.63/260/2021						213.33		
15.4	F.63/261/2021						226.67		do
	F.63/262/2021	5/2/2022	5/3/2022	Foundation	1.2.4	210 kg/cm2	222.22	220.74	
	F.63/263/2021						213.33		
15.5	F.63/264/2021						217.78		do
	F.63/265/2021	5/2/2022	5/3/2022	Foundation	1.2.4	210 kg/cm2	217.78	217.78	
	F.63/266/2021						217.78		
15.6	F.63/267/2021						222.22		do
	F.63/268/2021	5/2/2022	5/3/2022	Foundation	1.2.4	210 kg/cm2	222.22	222.22	
	F.63/269/2021						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of protection wall on upstream side of tank (Kadevi Tollem) at Xeldem in V.P. Assolda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
15.7	F.63/270/2021						217.78		No. WRD/WD XII/SD V/ F.63/184/2021-22 DATED: 23-02-2022
	F.63/271/2021	5/2/2022	5/3/2022	Foundation	1.2.4	210 kg/cm2	217.78	216.30	
	F.63/272/2021						213.33		
15.8	F.63/273/2021						217.78		do
	F.63/274/2021	5/2/2022	5/3/2022	Foundation	1.2.4	210 kg/cm2	213.33	216.30	
	F.63/275/2021						217.78		
16.1	F.63/276/2021						213.33		do
	F.63/277/2021	6/2/2022	6/3/2022	1st Lift	1.2.4	210 kg/cm2	217.78	216.30	
	F.63/278/2021						217.78		
16.2	F.63/279/2021						213.33		do
	F.63/280/2021	6/2/2022	6/3/2022	1st Lift	1.2.4	210 kg/cm2	217.78	217.78	
	F.63/281/2021						222.22		
16.3	F.63/282/2021						222.22		do
	F.63/283/2021	6/2/2022	6/3/2022	1st Lift	1.2.4	210 kg/cm2	222.22	219.26	
	F.63/284/2021						213.33		
16.4	F.63/285/2021						222.22		do
	F.63/286/2021	6/2/2022	6/3/2022	1st Lift	1.2.4	210 kg/cm2	226.67	220.74	
	F.63/287/2021						213.33		
16.5	F.63/288/2021						213.33		do
	F.63/289/2021	6/2/2022	6/3/2022	1st Lift	1.2.4	210 kg/cm2	217.78	217.78	
	F.63/290/2021						222.22		
16.6	F.63/291/2021						222.22		do
	F.63/292/2021	6/2/2022	6/3/2022	1st Lift	1.2.4	210 kg/cm2	222.22	219.26	
	F.63/293/2021						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of protection wall on upstream side of tank (Kadevi Tollem) at Xeldem in V.P. Assolda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
16.7	F.63/294/2021						226.67		No. WRD/WD XII/SD V/ F.63/184/2021-22 DATED: 23-02-2022
	F.63/295/2021	6/2/2022	6/3/2022	1st Lift	1.2.4	210 kg/cm2	213.33	217.78	
	F.63/296/2021						213.33		
16.8	F.63/297/2021						222.22		
	F.63/298/2021	6/2/2022	6/3/2022	1st Lift	1.2.4	210 kg/cm2	217.78	217.78	do
	F.63/299/2021						213.33		
17.1	F.63/300/2021						226.67		
	F.63/301/2021	7/2/2022	7/3/2022	1st Lift	1.2.4	210 kg/cm2	222.22	220.74	do
	F.63/302/2021						213.33		
17.2	F.63/303/2021						213.33		
	F.63/304/2021	7/2/2022	7/3/2022	1st Lift	1.2.4	210 kg/cm2	217.78	216.30	do
	F.63/305/2021						217.78		
17.3	F.63/306/2021						222.22		
	F.63/307/2021	7/2/2022	7/3/2022	1st Lift	1.2.4	210 kg/cm2	217.78	217.78	do
	F.63/308/2021						213.33		
17.4	F.63/309/2021						226.67		
	F.63/310/2021	7/2/2022	7/3/2022	1st Lift	1.2.4	210 kg/cm2	222.22	220.74	do
	F.63/311/2021						213.33		
18.1	F.63/312/2021						217.78		
	F.63/313/2021	8/2/2022	8/3/2022	Vertical Band	1.2.4	210 kg/cm2	217.78	217.78	do
	F.63/314/2021						217.78		
18.2	F.63/315/2021						222.22		
	F.63/316/2021	8/2/2022	8/3/2022	Vertical Band	1.2.4	210 kg/cm2	222.22	222.22	do
	F.63/317/2021						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of protection wall on upstream side of tank (Kadevi Tollem) at Xeldem in V.P. Assolda in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
19.1	F.63/318/2021						222.22		No. WRD/WD XII/SD V/ F.63/184/2021-22 DATED: 23-02-2022
	F.63/319/2021	16-02-2022	16-03-2022	Middle band	1.2.4	210 kg/cm2	217.78	217.78	
	F.63/320/2021						213.33		
19.2	F.63/321/2021						222.22		
	F.63/322/2021	16-02-2022	16-03-2022	Middle band	1.2.4	210 kg/cm2	222.22	220.74	do
	F.63/323/2021						217.78		
20.1	F.63/324/2021						217.78		
	F.63/325/2021	22-02-2022	22-03-2022	Top band	1.2.4	210 kg/cm2	217.78	217.78	do
	F.63/326/2021						217.78		
20.2	F.63/327/2021						217.78		
	F.63/328/2021	22-02-2022	22-03-2022	Top band	1.2.4	210 kg/cm2	222.22	219.26	do
	F.63/329/2021						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER