

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement and Strengthening the bank of nullah adjacent to Sapna Berrier, Borda within Margao Muncipal Area.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.66/06/2021						231.11		No.301/SD III/ WD III/ WRD/ 2022-23/10. DATED:- 08-04-2022.
	F.66/07/2021	12/3/2022	9/4/2022	Bottom Bed	1.1.5.3	200 kg/cm2	231.11	231.11	
	F.66/08/2021						231.11		
1.2	F.66/09/2021						240.00		
	F.66/10/2021	12/3/2022	9/4/2022	Bottom Bed	1.1.5.3	200 kg/cm2	231.11	235.56	do
	F.66/11/2021						235.56		
1.3	F.66/12/2021						244.44		
	F.66/13/2021	12/3/2022	9/4/2022	Bottom Bed	1.1.5.3	200 kg/cm2	240.00	238.52	do
	F.66/14/2021						231.11		
2.1	F.66/15/2021						240.00		
	F.66/16/2021	14-03-2022	11/4/2022	Wall on either side	1.1.5.3	200 kg/cm2	231.11	235.56	do
	F.66/17/2021						235.56		
2.2	F.66/18/2021						240.00		
	F.66/19/2021	14-03-2022	11/4/2022	Wall on either side	1.1.5.3	200 kg/cm2	235.56	237.04	do
	F.66/20/2021						235.56		
3.1	F.66/21/2021						244.44		
	F.66/22/2021	15-03-2022	12/4/2022	Wall on either side	1.1.5.3	200 kg/cm2	240.00	238.52	do
	F.66/23/2021						231.11		
3.2	F.66/24/2021						235.56		
	F.66/25/2021	15-03-2022	12/4/2022	Wall on either side	1.1.5.3	200 kg/cm2	231.11	234.08	do
	F.66/26/2021						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER