

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement of nallah in Sy.No. 109/6-G, 109/1-1 & 109/1-E in Village Sarzora in Velim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.68/01/2021						164.44		No. WRD/SD I/WD II/ F.Esst/708/2021-22. <b>DATED:- 21-01-2022</b>
	F.68/02/2021	11/1/2022	8/2/2022	Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.68/03/2021						164.44		
1.2	F.68/04/2021						168.89		do
	F.68/05/2021	11/1/2022	8/2/2022	Foundation	1.2.4	150 kg/cm2	173.33	168.89	
	F.68/06/2021						164.44		
2.1	F.68/07/2021						164.44		do
	F.68/08/2021	12/1/2022	9/2/2022	Foundation	1.2.4	150 kg/cm2	168.89	165.92	
	F.68/09/2021						164.44		
2.2	F.68/10/2021						164.44		do
	F.68/11/2021	12/1/2022	9/2/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.68/12/2021						168.89		
3.1	F.68/13/2021						168.89		do
	F.68/14/2021	13-01-2022	10/2/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.68/15/2021						164.44		
3.2	F.68/16/2021						164.44		do
	F.68/17/2021	13-01-2022	10/2/2022	Foundation	1.2.4	150 kg/cm2	173.33	167.40	
	F.68/18/2021						164.44		
4.1	F.68/19/2021						164.44		do
	F.68/20/2021	14-01-2022	11/2/2022	Wall	1.2.4	150 kg/cm2	168.89	165.92	
	F.68/21/2021						164.44		
4.2	F.68/22/2021						164.44		do
	F.68/23/2021	14-01-2022	11/2/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.68/24/2021						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Improvement of nallah in Sy.No. 109/6-G, 109/1-1 & 109/1-E in Village Sarzora in Velim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.68/25/2021						164.44		No. WRD/SD I/WD II/ F.Esst/708/2021-22. <b>DATED:- 21-01-2022</b>
	F.68/26/2021	15-01-2022	12/2/2022	Wall	1.2.4	150 kg/cm2	168.89	165.92	
	F.68/27/2021						164.44		
5.2	F.68/28/2021						164.44		do
	F.68/29/2021	15-01-2022	12/2/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.68/30/2021						168.89		
6.1	F.68/31/2021						168.89		do
	F.68/32/2021	17-01-2022	14-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.68/33/2021						164.44		
6.2	F.68/34/2021						164.44		do
	F.68/35/2021	17-01-2022	14-02-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.68/36/2021						164.44		
7.1	F.68/37/2021						164.44		do
	F.68/38/2021	18-01-2022	15-02-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.68/39/2021						164.44		
7.2	F.68/40/2021						173.33		do
	F.68/41/2021	18-01-2022	15-02-2022	Wall	1.2.4	150 kg/cm2	164.44	168.89	
	F.68/42/2021						168.89		
8.1	F.68/43/2021						168.89		do
	F.68/44/2021	19-01-2022	16-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.68/45/2021						164.44		
8.2	F.68/40/2021						164.44		do
	F.68/41/2021	19-01-2022	16-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.68/42/2021						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**