

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Open Type Bandhara across Caremol Nallah in Sy.No. 34/20 at Malkarnem in Sanguem Taluka.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.70/06/2021						168.89		No.SD I/ WD XII/ WRD/ F.47/27/2022-23. DATED:- 02-05-2022.
	F.70/07/2021	4/4/2022	2/5/2022	Pier Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.70/08/2021						164.44		
2	F.70/09/2021						164.44		
	F.70/10/2021	5/4/2022	3/5/2022	Centre cutoff middle cut off U/s Apron	1.2.4	150 kg/cm2	168.89	167.41	do
	F.70/11/2021						168.89		
3	F.70/12/2021						240.00		
	F.70/13/2021	6/4/2022	4/5/2022	Pier Foundation	1.1.5.3	200 kg/cm2	231.11	235.56	do
	F.70/14/2021						235.56		
4	F.70/15/2021						164.44		
	F.70/16/2021	7/4/2022	5/5/2022	Foundation of Retaining wall	1.2.4	150 kg/cm2	168.89	167.41	do
	F.70/17/2021						168.89		
5	F.70/18/2021						168.89		
	F.70/19/2021	8/4/2022	6/5/2022	Foundation of Retaining wall	1.2.4	150 kg/cm2	168.89	168.89	do
	F.70/20/2021						168.89		
6	F.70/21/2021						164.44		
	F.70/22/2021	8/4/2022	6/5/2022	1st Lift Right side Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.70/23/2021						168.89		
7	F.70/24/2021						168.89		
	F.70/25/2021	9/4/2022	7/5/2022	Right Wall abutment	1.2.4	150 kg/cm2	164.44	167.41	do
	F.70/26/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Open Type Bandhara across Caremol Nallah in Sy.No. 34/20 at Malkarnem in Sanguem Taluka.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
8	F.70/27/2021						244.44		No.SD I/ WD XII/ WRD/
	F.70/28/2021	9/4/2022	7/5/2022	Pier Wall	1.1.5.3	200 kg/cm2	240.00	238.52	F.47/27/2022-23.
	F.70/29/2021						231.11		DATED:- 02-05-2022.
9	F.70/30/2021						164.44		
	F.70/31/2021	11/4/2022	9/5/2022	PCC Wall 2nd Lift and Abutment	1.2.4	150 kg/cm2	168.89	167.41	do
	F.70/32/2021						168.89		
10	F.70/33/2021						231.11		
	F.70/34/2021	11/4/2022	9/5/2022	PCC Retaining wall 2nd Lift	1.1.5.3	200 kg/cm2	231.11	231.11	do
	F.70/35/2021						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER