

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement to tank (Spring) at Madlem V.P. Wadi Talaulim in Marcaim Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.80/05/2021						115.56		No. WRD/WD XI/SD IV/ W.F.432/506/2021-22 DATED:- 07-03-2022
	F.80/06/2021	2/3/2022	9/3/2022	Foundation	1.2.4	100 kg/cm2	120.00	118.52	
	F.80/07/2021						120.00		
2	F.80/08/2021						115.56		do
	F.80/09/2021	3/3/2022	10/3/2022	Foundation	1.2.4	100 kg/cm2	120.00	115.56	
	F.80/10/2021						111.11		
3	F.80/11/2021						115.56		do
	F.80/12/2021	4/3/2022	11/3/2022	Foundation	1.2.4	100 kg/cm2	124.44	117.04	
	F.80/13/2021						111.11		
4	F.80/14/2021						120.00		do
	F.80/15/2021	5/3/2022	12/3/2022	Foundation	1.2.4	100 kg/cm2	111.11	114.07	
	F.80/16/2021						111.11		
5	F.80/17/2021						115.56		No. WRD/WD XI/SD IV/ W.F.432/517/2021-22 DATED:- 15-03-2022
	F.80/18/2021	8/3/2022	15-03-2022	Above Foundation	1.2.4	100 kg/cm2	115.55	117.04	
	F.80/19/2021						120.00		
6	F.80/20/2021						115.56		do
	F.80/21/2021	9/3/2022	16-03-2022	Above Foundation	1.2.4	100 kg/cm2	120.00	115.56	
	F.80/22/2021						111.11		
7	F.80/23/2021						115.56		do
	F.80/24/2021	10/3/2022	17-03-2022	Above Foundation	1.2.4	100 kg/cm2	124.44	117.04	
	F.80/25/2021						111.11		
8	F.80/26/2021						120.00		do
	F.80/27/2021	11/3/2022	18-03-2022	Above Foundation	1.2.4	100 kg/cm2	115.56	115.56	
	F.80/28/2021						111.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER