

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of Retaining wall in Sy.No. 36/0 in Majorda Village in V.P. Majorda - utorda- Calata in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1.1	F.93/06/2021						164.44		No. WRD/SD I/WD II/ F.Estt/30/2022-23 DATED:- 06-04-2022.
	F.93/07/2021	23-03-2022	20-04-2022	Foundation	1.2.4	150 kg/cm ²	168.89	165.92	
	F.93/08/2021						164.44		
1.2	F.93/09/2021						164.44		
	F.93/10/2021	23-03-2022	20-04-2022	Foundation	1.2.4	150 kg/cm ²	168.89	167.41	do
	F.93/11/2021						168.89		
1.3	F.93/12/2021						164.44		
	F.93/13/2021	23-03-2022	20-04-2022	Foundation	1.2.4	150 kg/cm ²	164.44	164.44	do
	F.93/14/2021						164.44		
1.4	F.93/15/2021						168.89		
	F.93/16/2021	23-03-2022	20-04-2022	Foundation	1.2.4	150 kg/cm ²	168.89	167.41	do
	F.93/17/2021						164.44		
2.1	F.93/18/2021						168.89		
	F.93/19/2021	25-03-2022	22-04-2022	Foundation	1.2.4	150 kg/cm ²	164.44	167.41	do
	F.93/20/2021						168.89		
2.2	F.93/21/2021						168.89		
	F.93/22/2021	25-03-2022	22-04-2022	Foundation	1.2.4	150 kg/cm ²	164.44	165.92	do
	F.93/23/2021						164.44		
2.3	F.93/24/2021						168.89		
	F.93/25/2021	25-03-2022	22-04-2022	Foundation	1.2.4	150 kg/cm ²	164.44	165.92	do
	F.93/26/2021						164.44		
2.4	F.93/27/2021						168.89		
	F.93/28/2021	25-03-2022	22-04-2022	Foundation	1.2.4	150 kg/cm ²	168.89	168.89	do
	F.93/29/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall in Sy.No. 36/0 in Majorda Village in V.P. Majorda - utorda- Calata in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.93/30/2021						164.44		No. WRD/SD I/WD II/ F.Estt/30/2022-23 DATED:- 06-04-2022.
	F.93/31/2021	26-03-2022	23-04-2022	Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.93/32/2021						164.44		
3.2	F.93/33/2021						164.44		do
	F.93/34/2021	26-03-2022	23-04-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.93/35/2021						168.89		
3.3	F.93/36/2021						168.89		do
	F.93/37/2021	26-03-2022	23-04-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.93/38/2021						164.44		
3.4	F.93/39/2021						164.44		do
	F.93/40/2021	26-03-2022	23-04-2022	Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.93/41/2021						164.44		
4.1	F.93/42/2021						164.44		do
	F.93/43/2021	28-03-2022	25-04-2022	Wall	1.2.4	150 kg/cm2	168.89	165.92	
	F.93/44/2021						164.44		
4.2	F.93/45/2021						164.44		do
	F.93/46/2021	28-03-2022	25-04-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.93/47/2021						168.89		
4.3	F.93/48/2021						168.89		do
	F.93/49/2021	28-03-2022	25-04-2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.93/50/2021						168.89		
4.4	F.93/51/2021						168.89		do
	F.93/52/2021	28-03-2022	25-04-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.93/53/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall in Sy.No. 36/0 in Majorda Village in V.P. Majorda - utorda- Calata in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD			28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
5.1	F.93/54/2021						164.44		No. WRD/SD I/WD II/ F.Estt/30/2022-23 DATED:- 06-04-2022.
	F.93/55/2021	29-03-2022	26-04-2022	Foundation	1.2.4	150 kg/cm ²	164.44	164.44	
	F.93/56/2021						164.44		
5.2	F.93/57/2021						168.89		do
	F.93/58/2021	29-03-2022	26-04-2022	Foundation	1.2.4	150 kg/cm ²	164.44	165.92	
	F.93/59/2021						164.44		
5.3	F.93/60/2021						164.44		do
	F.93/61/2021	29-03-2022	26-04-2022	Foundation	1.2.4	150 kg/cm ²	168.89	165.92	
	F.93/62/2021						164.44		
5.4	F.93/63/2021						164.44		do
	F.93/64/2021	29-03-2022	26-04-2022	Foundation	1.2.4	150 kg/cm ²	164.44	165.92	
	F.93/65/2021						168.89		
6.1	F.93/66/2021						168.89		do
	F.93/67/2021	30-03-2022	27-04-2022	Wall	1.2.4	150 kg/cm ²	164.44	165.92	
	F.93/68/2021						164.44		
6.2	F.93/69/2021						164.44		do
	F.93/70/2021	30-03-2022	27-04-2022	Wall	1.2.4	150 kg/cm ²	164.44	164.44	
	F.93/71/2021						164.44		
6.3	F.93/72/2021						164.44		do
	F.93/73/2021	30-03-2022	27-04-2022	Wall	1.2.4	150 kg/cm ²	164.44	164.44	
	F.93/74/2021						164.44		
6.4	F.93/75/2021						164.44		do
	F.93/76/2021	30-03-2022	27-04-2022	Wall	1.2.4	150 kg/cm ²	164.44	165.92	
	F.93/77/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of Retaining wall in Sy.No. 36/0 in Majorda Village in V.P. Majorda - utorda- Calata in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
7.1	F.93/78/2021						164.44		No. WRD/SD I/WD II/ F.Esst/30/2022-23 DATED:- 06-04-2022.
	F.93/79/2021	31-03-2022	28-04-2022	Wall	1.2.4	150 kg/cm2	168.89	165.92	
	F.93/80/2021						164.44		
7.2	F.93/81/2021						164.44		do
	F.93/82/2021	31-03-2022	28-04-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.93/83/2021						168.89		
7.3	F.93/84/2021						168.89		do
	F.93/85/2021	31-03-2022	28-04-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.93/86/2021						164.44		
7.4	F.93/87/2021						164.44		do
	F.93/88/2021	31-03-2022	28-04-2022	Wall	1.2.4	150 kg/cm2	168.89	165.92	
	F.93/89/2021						164.44		
8.1	F.93/90/2021						164.44		do
	F.93/91/2021	2/4/2022	30-04-2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	
	F.93/92/2021						164.44		
8.2	F.93/93/2021						164.44		do
	F.93/94/2021	2/4/2022	30-04-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.93/95/2021						168.89		
8.3	F.93/96/2021						168.89		do
	F.93/97/2021	2/4/2022	30-04-2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.93/98/2021						168.89		
8.4	F.93/99/2021						168.89		do
	F.93/100/2021	2/4/2022	30-04-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.93/101/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of Retaining wall in Sy.No. 36/0 in Majorda Village in V.P. Majorda - utorda- Calata in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
9.1	F.93/102/2021						164.44		No. WRD/SD I/WD II/
	F.93/103/2021	4/4/2022	2/5/2022	Wall	1.2.4	150 kg/cm ²	160.00	162.96	F.Estt/30/2022-23
	F.93/104/2021						164.44		DATED:- 06-04-2022.
9.2	F.93/105/2021						164.44		
	F.93/106/2021	4/4/2022	2/5/2022	Wall	1.2.4	150 kg/cm ²	164.44	165.92	do
	F.93/107/2021						168.89		
9.3	F.93/108/2021						164.44		
	F.93/109/2021	4/4/2022	2/5/2022	Wall	1.2.4	150 kg/cm ²	164.44	165.92	do
	F.93/110/2021						168.89		
9.4	F.93/111/2021						168.89		
	F.93/112/2021	4/4/2022	2/5/2022	Wall	1.2.4	150 kg/cm ²	168.89	167.41	do
	F.93/113/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall in Sy.No. 36/0 in Majorda Village in V.P. Majorda - utorda- Calata in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.93/114/2021						164.44		No. WRD/SD I/WD II/ F.Estt/18/2022-23 DATED:- 04-04-2022.
	F.93/115/2021	17-03-2022	14-04-2022	Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.93/116/2021						164.44		
1.2	F.93/117/2021						164.44		do
	F.93/118/2021	17-03-2022	14-04-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.93/119/2021						168.89		
2.1	F.93/120/2021						168.89		do
	F.93/121/2021	21-03-2022	18-04-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.93/122/2021						164.44		
2.2	F.93/123/2021						164.44		do
	F.93/124/2021	21-03-2022	18-04-2022	Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.93/125/2021						164.44		
3.1	F.93/126/2021						164.44		do
	F.93/127/2021	23-03-2022	20-04-2022	Foundation	1.2.4	150 kg/cm2	168.89	165.92	
	F.93/128/2021						164.44		
3.2	F.93/129/2021						164.44		do
	F.93/130/2021	23-03-2022	20-04-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.93/131/2021						168.89		
4.1	F.93/132/2021						168.89		do
	F.93/133/2021	28-03-2022	25-04-2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.93/134/2021						168.89		
4.2	F.93/135/2021						168.89		do
	F.93/136/2021	28-03-2022	25-04-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.93/137/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of Retaining wall in Sy.No. 36/0 in Majorda Village in V.P. Majorda - utorda- Calata in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.93/138/2021						164.44		No. WRD/SD I/WD II/
	F.93/139/2021	30-03-2022	27-04-2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	F.Estt/18/2022-23
	F.93/140/2021						164.44		DATED:- 04-04-2022.
5.2	F.93/141/2021						168.89		
	F.93/142/2021	30-03-2022	27-04-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.93/143/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER