

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement of nallah from Sy.No. 178, 180 and 181 in V.P. Verna in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfnd- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.106/05/2021						164.44		No. WRD/SD I/ WD II/ F.Esst/874/2021-22 <b>DATED:- 30-03-2022</b>
	F.106/06/2021	19-03-2022	16-04-2022	Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.106/07/2021						164.44		
1.2	F.106/08/2021						164.44		do
	F.106/09/2021	19-03-2022	16-04-2022	Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.106/10/2021						164.44		
1.3	F.106/11/2021						164.44		do
	F.106/12/2021	19-03-2022	16-04-2022	Foundation	1.2.4	150 kg/cm2	168.89	164.44	
	F.106/13/2021						164.44		
1.4	F.106/14/2021						160.00		do
	F.106/15/2021	19-03-2022	16-04-2022	Foundation	1.2.4	150 kg/cm2	164.44	168.89	
	F.106/16/2021						168.89		
2.1	F.106/17/2021						160.00		do
	F.106/18/2021	21-03-2022	18-04-2022	Foundation	1.2.4	150 kg/cm2	168.89	164.44	
	F.106/19/2021						164.44		
2.2	F.106/20/2021						168.89		do
	F.106/21/2021	21-03-2022	18-04-2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.106/22/2021						168.89		
2.3	F.106/23/2021						168.89		do
	F.106/24/2021	21-03-2022	18-04-2022	Foundation	1.2.4	150 kg/cm2	173.33	170.37	
	F.106/25/2021						168.89		
2.4	F.106/26/2021						164.44		do
	F.106/27/2021	21-03-2022	18-04-2022	Foundation	1.2.4	150 kg/cm2	173.33	168.89	
	F.106/28/2021						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement of nallah from Sy.No. 178, 180 and 181 in V.P. Verna in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.106/29/2021						164.44		No. WRD/SD I/ WD II/
	F.106/30/2021	22-03-2022	19-04-2022	Foundation	1.2.4	150 kg/cm2	164.44	164.44	F.Esst/874/2021-22
	F.106/31/2021						164.44		<b>DATED:- 30-03-2022</b>
3.2	F.106/32/2021						160.00		
	F.106/33/2021	22-03-2022	19-04-2022	Foundation	1.2.4	150 kg/cm2	164.44	168.89	do
	F.106/34/2021						168.89		
4.1	F.106/35/2021						160.00		
	F.106/36/2021	24-03-2022	21-04-2022	Wall	1.2.4	150 kg/cm2	168.89	164.44	do
	F.106/37/2021						164.44		
4.2	F.106/38/2021						168.89		
	F.106/39/2021	24-03-2022	21-04-2022	Wall	1.2.4	150 kg/cm2	168.89	164.44	do
	F.106/40/2021						164.44		
4.3	F.106/41/2021						164.44		
	F.106/42/2021	24-03-2022	21-04-2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	do
	F.106/43/2021						164.44		
5.1	F.106/44/2021						160.00		
	F.106/45/2021	26-03-2022	23-04-2022	Wall	1.2.4	150 kg/cm2	164.44	168.89	do
	F.106/46/2021						168.89		
5.2	F.106/47/2021						160.00		
	F.106/48/2021	26-03-2022	23-04-2022	Wall	1.2.4	150 kg/cm2	168.89	164.44	do
	F.106/49/2021						164.44		
5.3	F.106/50/2021						168.89		
	F.106/51/2021	26-03-2022	23-04-2022	Wall	1.2.4	150 kg/cm2	168.89	164.44	do
	F.106/52/2021						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Improvement of nallah from Sy.No. 178, 180 and 181 in V.P. Verna in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfnd- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.1	F.106/53/2021						168.89		No. WRD/SD I/ WD II/ F.Esst/874/2021-22 <b>DATED:- 30-03-2022</b>
	F.106/54/2021	28-03-2022	25-04-2022	Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.106/55/2021						168.89		
6.2	F.106/56/2021						160.00		do
	F.106/57/2021	28-03-2022	25-04-2022	Wall	1.2.4	150 kg/cm2	168.89	165.93	
	F.106/58/2021						168.89		
6.3	F.106/59/2021						164.44		do
	F.106/60/2021	28-03-2022	25-04-2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.106/61/2021						168.89		
7.1	F.106/62/2021						168.89		do
	F.106/63/2021	29-03-2022	26-04-2022	Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.106/64/2021						168.89		
7.2	F.106/65/2021						168.89		do
	F.106/66/2021	29-03-2022	26-04-2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.106/67/2021						168.89		
7.3	F.106/68/2021						168.89		do
	F.106/69/2021	29-03-2022	26-04-2022	Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.106/70/2021						168.89		
7.4	F.106/71/2021						164.44		do
	F.106/72/2021	29-03-2022	26-04-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.106/73/2021						168.89		
8.1	F.106/74/2021						164.44		do
	F.106/75/2021	30-03-2022	27-04-2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	
	F.106/76/2021						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Improvement of nallah from Sy.No. 178, 180 and 181 in V.P. Verna in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
8.2	F.106/77/2021						164.44		No. WRD/SD I/ WD II/
	F.106/78/2021	30-03-2022	27-04-2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	F.Esst/874/2021-22
	F.106/79/2021						164.44		<b>DATED:- 30-03-2022</b>

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**