

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of outlet of spring and field channel in Sy.No. 367 & 368 in Ambelim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.111/05/2021						155.56		No. WRD/ SD I/ WD II/ F.Estt/863/2021-22. DATED: 29-03-2022
	F.111/06/2021	11/3/2022	8/4/2022	Foundation	1.2.4	150 kg/cm2	164.44	157.04	
	F.111/07/2021						151.11		
1.2	F.111/08/2021						160.00		do
	F.111/09/2021	11/3/2022	8/4/2022	Foundation	1.2.4	150 kg/cm2	155.56	158.52	
	F.111/10/2021						160.00		
2.1	F.111/11/2021						160.00		do
	F.111/12/2021	14-03-2022	11/4/2022	Foundation	1.2.4	150 kg/cm2	164.44	161.48	
	F.111/13/2021						160.00		
2.2	F.111/14/2021						151.11		do
	F.111/15/2021	14-03-2022	11/4/2022	Foundation	1.2.4	150 kg/cm2	164.44	158.52	
	F.111/16/2021						160.00		
3.1	F.111/17/2021						160.00		do
	F.111/18/2021	15-03-2022	12/4/2022	Wall	1.2.4	150 kg/cm2	160.00	158.52	
	F.111/19/2021						155.56		
3.2	F.111/20/2021						168.89		do
	F.111/21/2021	15-03-2022	12/4/2022	Wall	1.2.4	150 kg/cm2	155.56	160.00	
	F.111/22/2021						155.56		
4.1	F.111/23/2021						160.00		do
	F.111/24/2021	16-03-2022	13-04-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.111/25/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of outlet of spring and field channel in Sy.No. 367 & 368 in Ambelim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.2	F.111/26/2021						155.56		No. WRD/ SD I/ WD II/ F.Estt/863/2021-22. DATED: 29-03-2022
	F.111/27/2021	16-03-2022	13-04-2022	Wall	1.2.4	150 kg/cm2	155.56	157.04	
	F.111/28/2021						160.00		
5.1	F.111/29/2021						155.56		
	F.111/30/2021	19-03-2022	16-04-2022	Wall	1.2.4	150 kg/cm2	160.00	158.52	do
	F.111/31/2021						160.00		
5.2	F.111/32/2021						155.56		
	F.111/33/2021	19-03-2022	16-04-2022	Wall	1.2.4	150 kg/cm2	164.44	160.00	do
	F.111/34/2021						160.00		
6.1	F.111/35/2021						155.56		
	F.111/36/2021	20-03-2022	17-04-2022	Wall	1.2.4	150 kg/cm2	151.11	157.04	do
	F.111/37/2021						164.44		
6.2	F.111/38/2021						155.56		
	F.111/39/2021	20-03-2022	17-04-2022	Wall	1.2.4	150 kg/cm2	168.89	158.52	do
	F.111/40/2021						151.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER