

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Protection wall for nallah in Sy.No. 417 in Village Chinchinim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1.1	F.116/05/2021						155.56		No. WRD/ SD I/ WD II/ F.Estt/751 b/2021-22. DATED: 21-02-2022
	F.116/06/2021	5/2/2022	5/3/2022	Foundation	1.2.4	150 kg/cm ²	155.56	154.08	
	F.116/07/2021						151.11		
1.2	F.116/08/2021						160.00		do
	F.116/09/2021	5/2/2022	5/3/2022	Foundation	1.2.4	150 kg/cm ²	155.56	157.04	
	F.116/10/2021						155.56		
2.1	F.116/11/2021						160.00		do
	F.116/12/2021	8/2/2022	8/3/2022	Foundation	1.2.4	150 kg/cm ²	160.00	160.00	
	F.116/13/2021						160.00		
2.2	F.116/14/2021						155.56		do
	F.116/15/2021	8/2/2022	8/3/2022	Foundation	1.2.4	150 kg/cm ²	164.44	161.48	
	F.116/16/2021						164.44		
3.1	F.116/17/2021						160.00		do
	F.116/18/2021	10-02-202	10/3/2022	Foundation	1.2.4	150 kg/cm ²	160.00	158.52	
	F.116/19/2021						155.56		
3.2	F.116/20/2021						168.89		do
	F.116/21/2021	10-02-202	10/3/2022	Foundation	1.2.4	150 kg/cm ²	155.56	158.52	
	F.116/22/2021						151.11		
4.1	F.116/23/2021						160.00		do
	F.116/24/2021	12/2/2022	12/3/2022	Wall	1.2.4	150 kg/cm ²	160.00	161.48	
	F.116/25/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection wall for nallah in Sy.No. 417 in Village Chinchinim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.2	F.116/26/2021						155.56		No. WRD/ SD I/ WD II/ F.Estt/751 b/2021-22. DATED: 21-02-2022
	F.116/27/2021	12/2/2022	12/3/2022	Wall	1.2.4	150 kg/cm2	151.11	155.56	
	F.116/28/2021						160.00		
5.1	F.116/29/2021						155.56		
	F.116/30/2021	15-02-2022	15-03-2022	Wall	1.2.4	150 kg/cm2	151.11	154.08	do
	F.116/31/2021						155.56		
5.2	F.116/32/2021						155.56		
	F.116/33/2021	15-02-2022	15-03-2022	Wall	1.2.4	150 kg/cm2	160.00	157.04	do
	F.116/34/2021						155.56		
6.1	F.116/35/2021						155.56		
	F.116/36/2021	17-02-2022	17-03-2022	Wall	1.2.4	150 kg/cm2	151.11	152.59	do
	F.116/37/2021						151.11		
6.2	F.116/38/2021						155.56		
	F.116/39/2021	17-02-2022	17-03-2022	Wall	1.2.4	150 kg/cm2	160.00	155.56	do
	F.116/40/2021						151.11		
7.1	F.116/41/2021						155.56		
	F.116/42/2021	19-02-2022	19-03-2022	Wall	1.2.4	150 kg/cm2	160.00	155.56	do
	F.116/43/2021						151.11		
7.2	F.116/44/2021						155.56		
	F.116/45/2021	19-02-2022	19-03-2022	Wall	1.2.4	150 kg/cm2	160.00	158.52	do
	F.116/46/2021						160.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER