

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to traditional irrigation tank at Daigode in V.P. Querim in Priol Constituency of Ponda Taluka.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
1.1	F.29/06/2021						168.89		No. WRD/WD XI/ SD IV/ W.F.500/475/2021-22. <b>DATED: 01-02-2022</b>
	F.29/07/2021	5/2/2022	5/3/2022	For Foundation	1.2.4	150 kg/cm <sup>2</sup>	164.44	167.41	
	F.29/08/2021						168.89		
1.2	F.29/09/2021						168.89		do
	F.29/10/2021	5/2/2022	5/3/2022	For Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	168.89	
	F.29/11/2021						168.89		
2.1	F.29/12/2021						173.33		do
	F.29/13/2021	7/2/2022	7/3/2022	For Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	168.89	
	F.29/14/2021						164.44		
2.2	F.29/15/2021						173.33		do
	F.29/16/2021	7/2/2022	7/3/2022	For Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	170.37	
	F.29/17/2021						168.89		
3.1	F.29/18/2021						160.00		do
	F.29/19/2021	8/2/2022	8/3/2022	For Foundation	1.2.4	150 kg/cm <sup>2</sup>	164.44	162.96	
	F.29/20/2021						164.44		
3.2	F.29/21/2021						164.44		do
	F.29/22/2021	8/2/2022	8/3/2022	For Foundation	1.2.4	150 kg/cm <sup>2</sup>	164.44	164.44	
	F.29/23/2021						164.44		
4.1	F.29/24/2021						164.44		do
	F.29/25/2021	9/2/2022	9/3/2022	For Foundation	1.2.4	150 kg/cm <sup>2</sup>	164.44	165.92	
	F.29/26/2021						168.89		
4.2	F.29/27/2021						164.44		do
	F.29/28/2021	9/2/2022	9/3/2022	For Foundation	1.2.4	150 kg/cm <sup>2</sup>	164.44	164.44	
	F.29/29/2021						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**