

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Protection to nallah side in Sy.No. 101/2 Village Codar in Shiroda Constituency.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.122/05/2021						124.44		No. WRD/WD XI/ SD IV/ F.CF/42/2022-23. <b>DATED: 20-04-2022.</b>
	F.122/06/2021	29-03-2022	26-04-2022	Foundation	1.3.6	100 kg/cm2	120.00	124.44	
	F.122/07/2021						128.89		
1.2	F.122/08/2021						128.89		do
	F.122/09/2021	29-03-2022	26-04-2022	Foundation	1.3.6	100 kg/cm2	124.44	125.92	
	F.122/10/2021						124.44		
2.1	F.122/11/2021						128.89		do
	F.122/12/2021	31-03-2022	27-04-2022	Foundation	1.3.6	100 kg/cm2	124.44	124.44	
	F.122/13/2021						120.00		
2.2	F.122/14/2021						124.44		do
	F.122/15/2021	31-03-2022	27-04-2022	Foundation	1.3.6	100 kg/cm2	128.89	125.92	
	F.122/16/2021						124.44		
3.1	F.122/17/2021						128.89		do
	F.122/18/2021	4/4/2022	2/5/2022	Foundation	1.3.6	100 kg/cm2	120.00	124.44	
	F.122/19/2021						124.44		
3.2	F.122/20/2021						120.00		do
	F.122/21/2021	4/4/2022	2/5/2022	Foundation	1.3.6	100 kg/cm2	124.44	121.48	
	F.122/22/2021						120.00		
4.1	F.122/23/2021						124.44		do
	F.122/24/2021	5/4/2022	3/5/2022	Foundation	1.3.6	100 kg/cm2	128.89	124.44	
	F.122/25/2021						120.00		
4.2	F.122/26/2021						124.44		do
	F.122/27/2021	5/4/2022	3/5/2022	Foundation	1.3.6	100 kg/cm2	124.44	122.96	
	F.122/28/2021						120.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**