

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent Construction of retaining wall near house of Ambala Purohit ward no.2 in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1.1	F.124/06/2021						168.89		No.WRD/WDXI/SD IV/ WF.487/100/2022-23. DATED:- 07-06-2022.
	F.124/07/2021	10/5/2022	7/6/2022	Foundation	1.2.4	150 kg/cm ²	168.89	168.89	
	F.124/08/2021						168.89		
1.2	F.124/09/2021						168.89		do
	F.124/10/2021	10/5/2022	7/6/2022	Foundation	1.2.4	150 kg/cm ²	173.33	170.37	
	F.124/11/2021						168.89		
2.1	F.124/12/2021						168.89		do
	F.124/13/2021	11/5/2022	8/6/2022	Foundation	1.2.4	150 kg/cm ²	164.44	167.41	
	F.124/14/2021						168.89		
2.2	F.124/15/2021						168.89		do
	F.124/16/2021	11/5/2022	8/6/2022	Foundation	1.2.4	150 kg/cm ²	164.44	168.89	
	F.124/17/2021						173.33		
3.1	F.124/18/2021						168.89		do
	F.124/19/2021	12/5/2022	9/6/2022	Wall	1.2.4	150 kg/cm ²	164.44	168.89	
	F.124/20/2021						173.33		
3.2	F.124/21/2021						168.89		do
	F.124/22/2021	12/5/2022	9/6/2022	Wall	1.2.4	150 kg/cm ²	168.89	167.41	
	F.124/23/2021						164.44		
4.1	F.124/24/2021						168.89		do
	F.124/25/2021	13-05-2022	10/6/2022	Wall	1.2.4	150 kg/cm ²	173.33	170.37	
	F.124/26/2021						168.89		
4.2	F.124/27/2021						164.44		do
	F.124/28/2021	13-05-2022	10/6/2022	Wall	1.2.4	150 kg/cm ²	173.33	168.89	
	F.124/29/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent Construction of retaining wall near house of Ambala Purohit ward no.2 in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5	F.124/30/2021						164.44		No.WRD/WDXI/SD IV/
	F.124/31/2021	14-05-2022	11/6/2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	WF.487/100/2022-23.
	F.124/32/2021						168.89		DATED:- 07-06-2022.
6	F.124/33/2021						168.89		
	F.124/34/2021	15-05-2022	12/6/2022	Wall	1.2.4	150 kg/cm2	168.89	168.89	do
	F.124/35/2021						168.89		
7	F.124/36/2021						168.89		
	F.124/37/2021	16-05-2022	13-06-2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	do
	F.124/38/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER