

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development of pond in Sy. No. 367 in Villge Velim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfnd- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.125/01/2021						168.89		No.WRD/SD I/ WD II/
	F.125/02/2021	4/3/2022	1/4/2022	Foundation	1.2.4	150 kg/cm2	164.44	167.41	F.Estt/864/2022-23
	F.125/03/2021						168.89		DATED:- 29-03-2022
1.2	F.125/04/2021						168.89		
	F.125/05/2021	4/3/2022	1/4/2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	do
	F.125/06/2021						168.89		
2.1	F.125/07/2021						164.44		
	F.125/08/2021	5/3/2022	2/4/2022	Foundation	1.2.4	150 kg/cm2	168.89	165.92	do
	F.125/09/2021						164.44		
2.2	F.125/10/2021						164.44		
	F.125/11/2021	5/3/2022	2/4/2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	F.125/12/2021						168.89		
3.1	F.125/13/2021						160.00		
	F.125/14/2021	7/3/2022	4/4/2022	Wall	1.2.4	150 kg/cm2	164.44	162.96	do
	F.125/15/2021						164.44		
3.2	F.125/16/2021						164.44		
	F.125/17/2021	7/3/2022	4/4/2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	do
	F.125/18/2021						164.44		
4.1	F.125/19/2021						164.44		
	F.125/20/2021	8/3/2022	5/4/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.125/21/2021						168.89		
4.2	F.125/22/2021						164.44		
	F.125/23/2021	8/3/2022	5/4/2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	do
	F.125/24/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development of pond in Sy. No. 367 in Villge Velim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.125/25/2021						168.89		No.WRD/SD I/ WD II/
	F.125/26/2021	9/3/2022	6/4/2022	Wall	1.2.4	150 kg/cm2	168.89	168.89	F.Estt/864/2022-23
	F.125/27/2021						168.89		DATED:- 29-03-2022
5.2	F.125/28/2021						160.00		
	F.125/29/2021	9/3/2022	6/4/2022	Wall	1.2.4	150 kg/cm2	168.89	165.93	do
	F.125/30/2021						168.89		
6.1	F.125/31/2021						164.44		
	F.125/32/2021	11/3/2022	8/4/2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	do
	F.125/33/2021						168.89		
6.2	F.125/34/2021						168.89		
	F.125/35/2021	11/3/2022	8/4/2022	Wall	1.2.4	150 kg/cm2	168.89	168.89	do
	F.125/36/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER