

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of flood protection wall for the Verna Lake in Sy.No. 129/4 & 129/3 A at Ambulor in V.P. Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.134/05/2021						164.44		No. WRD/SD I/WD II/ F.Esst/34/2022-23. DATED:- 13-04-2022
	F.134/06/2021	2/4/2022	30-04-2022	Foundation	1.2.4	150 kg/cm2	173.33	168.89	
	F.134/07/2021						168.89		
1.2	F.134/08/2021						168.89		do
	F.134/09/2021	2/4/2022	30-04-2022	Foundation	1.2.4	150 kg/cm2	173.33	168.89	
	F.134/10/2021						164.44		
1.3	F.134/11/2021						164.44		do
	F.134/12/2021	2/4/2022	30-04-2022	Foundation	1.2.4	150 kg/cm2	168.89	165.92	
	F.134/13/2021						164.44		
2.1	F.134/14/2021						168.89		do
	F.134/15/2021	3/4/2022	1/5/2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.134/16/2021						168.89		
2.2	F.134/17/2021						168.89		do
	F.134/18/2021	3/4/2022	1/5/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.134/19/2021						164.44		
2.3	F.134/20/2021						164.44		do
	F.134/21/2021	3/4/2022	1/5/2022	Foundation	1.2.4	150 kg/cm2	173.33	167.40	
	F.134/22/2021						164.44		
3.1	F.134/23/2021						164.44		do
	F.134/24/2021	5/4/2022	3/5/2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.134/25/2021						168.89		
3.2	F.134/26/2021						173.33		do
	F.134/27/2021	5/4/2022	3/5/2022	Wall	1.2.4	150 kg/cm2	164.44	168.89	
	F.134/28/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of flood protection wall for the Verna Lake in Sy.No. 129/4 & 129/3 A at Ambulor in V.P. Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.3	F.134/29/2021						168.89		No. WRD/SD I/WD II/ F.Esst/34/2022-23. DATED:- 13-04-2022
	F.134/30/2021	5/4/2022	3/5/2022	Wall	1.2.4	150 kg/cm2	168.89	170.37	
	F.134/31/2021						173.33		
4.1	F.134/32/2021						164.44		do
	F.134/33/2021	6/4/2022	4/5/2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.134/34/2021						168.89		
4.2	F.134/35/2021						168.89		do
	F.134/36/2021	6/4/2022	4/5/2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.134/37/2021						164.44		
4.3	F.134/38/2021						173.33		do
	F.134/39/2021	6/4/2022	4/5/2022	Wall	1.2.4	150 kg/cm2	173.33	170.37	
	F.134/40/2021						164.44		
5.1	F.134/41/2021						164.44		do
	F.134/42/2021	9/4/2022	7/5/2022	Wall	1.2.4	150 kg/cm2	168.89	165.92	
	F.134/43/2021						164.44		
5.2	F.134/44/2021						173.33		do
	F.134/45/2021	9/4/2022	7/5/2022	Wall	1.2.4	150 kg/cm2	164.44	168.89	
	F.134/46/2021						168.89		
5.3	F.134/47/2021						168.89		do
	F.134/48/2021	9/4/2022	7/5/2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.134/49/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER