

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development of water bodies in Sy.No. 24-2 in Village Betalbatim in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1.1	F.138/06/2021						222.22		No. WRD/SD I/WD II/
	F.138/07/2021	30-03-2022	27-04-2022	Foundation	1.2.4	210 kg/cm ²	231.11	225.18	F.Esst/76/2022-23.
	F.138/08/2021						222.22		DATED: 26-04-2022.
1.2	F.138/09/2021						235.56		
	F.138/10/2021	30-03-2022	27-04-2022	Foundation	1.2.4	210 kg/cm ²	217.78	223.71	do
	F.138/11/2021						217.78		
2.1	F.138/12/2021						231.11		
	F.138/13/2021	31-03-2022	28-04-2022	Foundation	1.2.4	210 kg/cm ²	217.78	222.22	do
	F.138/14/2021						217.78		
2.2	F.138/15/2021						222.22		
	F.138/16/2021	31-03-2022	28-04-2022	Foundation	1.2.4	210 kg/cm ²	226.67	223.70	do
	F.138/17/2021						222.22		
3	F.138/18/2021						235.56		
	F.138/19/2021	4/4/2022	2/5/2022	Wall support pillars	1.2.4	210 kg/cm ²	217.78	225.19	do
	F.138/20/2021						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER