

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nalalh near Viraj Parab house at Shindolim in V.P. Sancoale in Cortalim Constituency.

SAMPLE SENT BY: AE, SD II, WD II, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.33/06/2021						120.00		No. WRD/WD II/SD II/ F.03/264/2021-22. DATED: 14-12-2021
	F.33/07/2021	7/12/2021	4/1/2022	Foundation Ch.0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	115.56	120.00	
	F.33/08/2021			(RHS)			124.44		
1.2	F.33/09/2021						111.11		do
	F.33/10/2021	7/12/2021	4/1/2022	Foundation Ch.0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	120.00	118.52	
	F.33/11/2021			(RHS)			124.44		
1.3	F.33/12/2021						115.56		do
	F.33/13/2021	7/12/2021	4/1/2022	Foundation Ch.0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	124.44	120.00	
	F.33/14/2021			(RHS)			120.00		
1.4	F.33/15/2021						115.56		do
	F.33/16/2021	7/12/2021	4/1/2022	Foundation Ch.0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	124.44	118.52	
	F.33/17/2021			(RHS)			115.56		
2.1	F.33/18/2021						120.00		do
	F.33/19/2021	8/12/2021	5/1/2022	Foundation Ch.0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	124.44	120.00	
	F.33/20/2021			(LHS)			115.56		
2.2	F.33/21/2021						124.44		do
	F.33/22/2021	8/12/2021	5/1/2022	Foundation Ch.0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	120.00	118.52	
	F.33/23/2021			(LHS)			111.11		
2.3	F.33/24/2021						120.00		do
	F.33/25/2021	8/12/2021	5/1/2022	Foundation Ch.0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	124.44	120.00	
	F.33/26/2021			(LHS)			115.56		
2.4	F.33/27/2021						124.44		do
	F.33/28/2021	8/12/2021	5/1/2022	Foundation Ch.0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	120.00	118.52	
	F.33/29/2021			(LHS)			111.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nalalh near Viraj Parab house at Shindolim in V.P. Sancoale in Cortalim Constituency.

SAMPLE SENT BY: AE, SD II, WD II, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.33/30/2021						111.11		No. WRD/WD II/SD II/ F.03/264/2021-22. DATED: 14-12-2021
	F.33/31/2021	9/12/2021	6/1/2022	Above Foundation Ch. 0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	120.00	118.52	
	F.33/32/2021			(RHS)			124.44		
3.2	F.33/33/2021						115.56		do
	F.33/34/2021	9/12/2021	6/1/2022	Above Foundation Ch. 0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	124.44	120.00	
	F.33/35/2021			(RHS)			120.00		
3.3	F.33/36/2021						115.56		do
	F.33/37/2021	9/12/2021	6/1/2022	Above Foundation Ch. 0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	124.44	118.52	
	F.33/38/2021			(RHS)			115.56		
3.4	F.33/39/2021						120.00		do
	F.33/40/2021	9/12/2021	6/1/2022	Above Foundation Ch. 0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	124.44	120.00	
	F.33/41/2021			(RHS)			115.56		
4.1	F.33/42/2021						124.44		do
	F.33/43/2021	10/12/2021	7/1/2022	Above Foundation Ch. 0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	128.89	125.92	
	F.33/44/2021			(LHS)			124.44		
4.2	F.33/45/2021						128.89		do
	F.33/46/2021	10/12/2021	7/1/2022	Above Foundation Ch. 0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	128.89	127.41	
	F.33/47/2021			(LHS)			124.44		
4.3	F.33/48/2021						120.00		do
	F.33/49/2021	10/12/2021	7/1/2022	Above Foundation Ch. 0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	124.44	121.48	
	F.33/50/2021			(LHS)			120.00		
4.4	F.33/51/2021						124.44		do
	F.33/52/2021	10/12/2021	7/1/2022	Above Foundation Ch. 0 mt to Ch. 20 mts	1.3.6	100 kg/cm2	128.89	125.92	
	F.33/53/2021			(LHS)			124.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nalalh near Viraj Parab house at Shindolim in V.P. Sancoale in Cortalim Constituency.

SAMPLE SENT BY: AE, SD II, WD II, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.33/54/2021						120.00		No. WRD/WD II/SD II/
	F.33/55/2021	13-12-2021	10/1/2022	Bands & Coping Ch.0.00 to 20.00	1.3.6	100 kg/cm2	115.56	120.00	F.03/264/2021-22.
	F.33/56/2021			(RHS & LHS)			124.44		DATED: 14-12-2021
5.2	F.33/57/2021						111.11		
	F.33/58/2021	13-12-2021	10/1/2022	Bands & Coping Ch.0.00 to 20.00	1.3.6	100 kg/cm2	120.00	118.52	do
	F.33/59/2021			(RHS & LHS)			124.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER