

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to Katcha Canal for Shitte Paikpan at Cazur Village in V.P. Cavrem- Pirla in Sanguem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.98/06/2021						164.44		No.WRD/SD I/ WD XII/ F.47/334/2021-22. <b>DATED:- 16-03-2022</b>
	F.98/07/2021	25-02-2022	25-03-2022	Ch.320 mts to 360.00 mts Bed of Canal	1.2.4	150kg/cm2	164.44	165.92	
	F.98/08/2021						168.89		
1.2	F.98/09/2021						168.89		
	F.98/10/2021	25-02-2022	25-03-2022	Ch.320 mts to 360.00 mts Bed of Canal	1.2.4	150kg/cm2	168.89	168.89	do
	F.98/11/2021						168.89		
2.1	F.98/12/2021						173.33		
	F.98/13/2021	25-02-2022	25-03-2022	Ch.360 mts to 400.00 mts Bed of Canal	1.2.4	150kg/cm2	168.89	168.89	do
	F.98/14/2021						164.44		
2.2	F.98/15/2021						168.89		
	F.98/16/2021	25-02-2022	25-03-2022	Ch.360 mts to 400.00 mts Bed of Canal	1.2.4	150kg/cm2	164.44	165.92	do
	F.98/17/2021						164.44		
3.1	F.98/18/2021						164.44		
	F.98/19/2021	28-02-2022	28-03-2022	Ch.320 mts to 360.00 mts Canal wall	1.2.4	150kg/cm2	164.44	164.44	do
	F.98/20/2021			on both side			164.44		
3.2	F.98/21/2021						168.89		
	F.98/22/2021	28-02-2022	28-03-2022	Ch.320 mts to 360.00 mts Canal wall	1.2.4	150kg/cm2	160.00	164.44	do
	F.98/23/2021			on both side			164.44		
4.1	F.98/24/2021						164.44		
	F.98/25/2021	28-02-2022	28-03-2022	Ch.360 mts to 400.00 mts Canal wall	1.2.4	150kg/cm2	164.44	165.92	do
	F.98/26/2021			on both side			168.89		
4.2	F.98/27/2021						164.44		
	F.98/28/2021	28-02-2022	28-03-2022	Ch.360 mts to 400.00 mts Canal wall	1.2.4	150kg/cm2	164.44	164.44	do
	F.98/29/2021			on both side			164.44		

**Sandip Parab  
JUNIOR ENGINEER.**

**Pravin C Parsekar  
ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to Katcha Canal for Shitte Paikpan at Cazur Village in V.P. Cavrem- Pirla in Sanguem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.98/30/2021						168.89		No.WRD/SD I/ WD XII/ F.47/334/2021-22. <b>DATED:- 16-03-2022</b>
	F.98/31/2021	2/3/2022	30-03-2022	Ch.400 mts to 440.00 mts Bed of Canal	1.2.4	150kg/cm2	164.44	167.41	
	F.98/32/2021						168.89		
5.2	F.98/33/2021						168.89		
	F.98/34/2021	2/3/2022	30-03-2022	Ch.400 mts to 440.00 mts Bed of Canal	1.2.4	150kg/cm2	168.89	168.89	do
	F.98/35/2021						168.89		
6.1	F.98/36/2021						173.33		
	F.98/37/2021	2/3/2022	30-03-2022	Ch.440 mts to 480.00 mts Bed of Canal	1.2.4	150kg/cm2	168.89	168.89	do
	F.98/38/2021						164.44		
6.2	F.98/39/2021						164.44		
	F.98/40/2021	2/3/2022	30-03-2022	Ch.440 mts to 480.00 mts Bed of Canal	1.2.4	150kg/cm2	168.89	167.41	do
	F.98/41/2021						168.89		
7.1	F.98/42/2021						168.89		
	F.98/43/2021	4/3/2022	1/4/2022	Ch.400 mts to 440.00 mts Canal wall	1.2.4	150kg/cm2	164.44	165.92	do
	F.98/44/2021			on both side			164.44		
7.2	F.98/45/2021						164.44		
	F.98/46/2021	4/3/2022	1/4/2022	Ch.400 mts to 440.00 mts Canal wall	1.2.4	150kg/cm2	164.44	164.44	do
	F.98/47/2021			on both side			164.44		
8.1	F.98/48/2021						164.44		
	F.98/49/2021	4/3/2022	1/4/2022	Ch.440 mts to 480.00 mts Canal wall	1.2.4	150kg/cm2	164.44	165.92	do
	F.98/50/2021			on both side			168.89		
8.2	F.98/51/2021						164.44		
	F.98/52/2021	4/3/2022	1/4/2022	Ch.440 mts to 480.00 mts Canal wall	1.2.4	150kg/cm2	164.44	164.44	do
	F.98/53/2021			on both side			164.44		

**Sandip Parab**  
**JUNIOR ENGINEER.**

**Pravin C Parsekar**  
**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to Katcha Canal for Shitte Paikpan at Cazur Village in V.P. Cavrem- Pirla in Sanguem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	F.98/54/2021						164.44		No.WRD/SD I/ WD XII/ F.47/334/2021-22. <b>DATED:- 16-03-2022</b>
	F.98/55/2021	5/3/2022	2/4/2022	Ch.480 mts to 520.00 mts Bed of Canal	1.2.4	150kg/cm2	164.44	164.44	
	F.98/56/2021						164.44		
9.2	F.98/57/2021						168.89		
	F.98/58/2021	5/3/2022	2/4/2022	Ch.480 mts to 520.00 mts Bed of Canal	1.2.4	150kg/cm2	164.44	165.92	do
	F.98/59/2021						164.44		
10.1	F.98/60/2021						164.44		
	F.98/61/2021	5/3/2022	2/4/2022	Ch.520 mts to 560.00 mts Bed of Canal	1.2.4	150kg/cm2	164.44	164.44	do
	F.98/62/2021						164.44		
10.2	F.98/63/2021						164.44		
	F.98/64/2021	5/3/2022	2/4/2022	Ch.520 mts to 560.00 mts Bed of Canal	1.2.4	150kg/cm2	164.44	165.92	do
	F.98/65/2021						168.89		
11.1	F.98/66/2021						168.89		
	F.98/67/2021	7/3/2022	4/4/2022	Ch.480 mts to 520.00 mts Canal wall	1.2.4	150kg/cm2	164.44	165.92	do
	F.98/68/2021			on both side			164.44		
11.2	F.98/69/2021						164.44		
	F.98/70/2021	7/3/2022	4/4/2022	Ch.480 mts to 520.00 mts Canal wall	1.2.4	150kg/cm2	168.89	165.92	do
	F.98/71/2021			on both side			164.44		
12.1	F.98/72/2021						164.44		
	F.98/73/2021	7/3/2022	4/4/2022	Ch.520 mts to 560.00 mts Canal wall	1.2.4	150kg/cm2	164.44	164.44	do
	F.98/74/2021			on both side			164.44		
12.2	F.98/75/2021						164.44		
	F.98/76/2021	7/3/2022	4/4/2022	Ch.520 mts to 560.00 mts Canal wall	1.2.4	150kg/cm2	164.44	165.92	do
	F.98/77/2021			on both side			168.89		

**Sandip Parab  
JUNIOR ENGINEER.**

**Pravin C Parsekar  
ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to Katcha Canal for Shitte Paikpan at Cazur Village in V.P. Cavrem- Pirla in Sanguem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
13.1	F.98/78/2021						168.89		No.WRD/SD I/ WD XII/
	F.98/79/2021	9/3/2022	6/4/2022	Ch.560 mts to 600.00 mts Bed of Canal	1.2.4	150kg/cm2	168.89	167.41	F.47/334/2021-22.
	F.98/80/2021						164.44		<b>DATED:- 16-03-2022</b>
13.2	F.98/81/2021						164.44		
	F.98/82/2021	9/3/2022	6/4/2022	Ch.560 mts to 600.00 mts Bed of Canal	1.2.4	150kg/cm2	164.44	165.92	do
	F.98/83/2021						168.89		
14.1	F.98/84/2021						164.44		
	F.98/85/2021	14-03-2022	11/4/2022	Ch.560 mts to 600.00 mts Canal wall	1.2.4	150kg/cm2	164.44	165.92	do
	F.98/86/2021			on both side			168.89		
14.2	F.98/87/2021						168.89		
	F.98/88/2021	14-03-2022	11/4/2022	Ch.560 mts to 600.00 mts Canal wall	1.2.4	150kg/cm2	168.89	167.41	do
	F.98/89/2021			on both side			164.44		

**Sandip Parab  
JUNIOR ENGINEER.**

**Pravin C Parsekar  
ASSISTANT ENGINEER**