

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Procurement of FRP gates and wooden planks for Khare, Morjojiem Panna and Bokdamol Gurvavoll in V.P. Agonda in Canacona Taluka.

**SAMPLE SENT BY:** AE, SD II, WD XI, WRD, Canacona- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.40/05/2021						115.56		No. WRD/WD XI/ SD II/
	F.40/06/2021	15-12-2021	22-12-2021	F.R.P. 1	1.2.4	100 kg/cm2	120.00	118.52	F.36/201/2021-22.
	F.40/07/2021						120.00		<b>DATED: 16-12-2021</b>

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Procurement of FRP gates and wooden planks for Khare, Morjojiem Panna and Bokdamol Gurvavoll in V.P. Agonda in Canacona Taluka.

**SAMPLE SENT BY:** AE, SD II, WD XI, WRD, Canacona- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.40/08/2021						168.89		No. WRD/WD XI/ SD II/
	F.40/09/2021	15-12-2021	12/1/2022	F.R.P. 1	1.2.4	150 kg/cm2	164.44	165.92	F.36/201/2021-22.
	F.40/10/2021						164.44		<b>DATED: 16-12-2021</b>

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**