

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the pond in Sy.No. 177/3 (Grand pulvaddo) and Construction of Retaining wall in Sy.No. 184/5-A in Benaulim Village
in Benaulim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.43/05/2021						164.44		No. WRD/SD I/WD II/ F. Estt/697/2021-22. DATED:- 17-01-2022.
	F.43/06/2021	3/1/2022	31-01-2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.43/07/2021						164.44		
1.2	F.43/08/2021						164.44		do
	F.43/09/2021	3/1/2022	31-01-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.43/10/2021						168.89		
2.1	F.43/11/2021						164.44		do
	F.43/12/2021	4/1/2022	1/2/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.43/13/2021						168.89		
2.2	F.43/14/2021						168.89		do
	F.43/15/2021	4/1/2022	1/2/2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.43/16/2021						164.44		
3.1	F.43/17/2021						164.44		do
	F.43/18/2021	5/1/2022	2/2/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.43/19/2021						168.89		
3.2	F.43/20/2021						168.89		do
	F.43/21/2021	5/1/2022	2/2/2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.43/22/2021						164.44		
4.1	F.43/23/2021						168.89		do
	F.43/24/2021	6/1/2022	3/2/2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.43/25/2021						164.44		
4.2	F.43/26/2021						168.89		do
	F.43/27/2021	6/1/2022	3/2/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.43/28/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the pond in Sy.No. 177/3 (Grand pulvaddo) and Construction of Retaining wall in Sy.No. 184/5-A in Benaulim Village in Benaulim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.43/29/2021						164.44		No. WRD/SD I/WD II/ F. Estt/697/2021-22. DATED:- 17-01-2022.
	F.43/30/2021	8/1/2022	5/2/2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.43/31/2021						164.44		
5.2	F.43/32/2021						164.44		do
	F.43/33/2021	8/1/2022	5/2/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.43/34/2021						168.89		
6.1	F.43/35/2021						168.89		do
	F.43/36/2021	10/1/2022	7/2/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.43/37/2021						164.44		
6.2	F.43/38/2021						164.44		do
	F.43/39/2021	10/1/2022	7/2/2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.43/40/2021						164.44		
7.1	F.43/41/2021						164.44		do
	F.43/90/2021	11/1/2022	8/2/2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.43/91/2021						164.44		
7.2	F.43/92/2021						164.44		do
	F.43/93/2021	11/1/2022	8/2/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.43/94/2021						168.89		
8.1	F.43/95/2021						168.89		do
	F.43/96/2021	13-01-2022	10/2/2022	Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	F.43/97/2021						168.89		
8.2	F.43/98/2021						168.89		do
	F.43/99/2021	13-01-2022	10/2/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.43/100/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the pond in Sy.No. 177/3 (Grand pulvaddo) and Construction of Retaining wall in Sy.No. 184/5-A in Benaulim Village in Benaulim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	F.43/101/2021						164.44		No. WRD/SD I/WD II/ F. Estt/697/2021-22. DATED:- 17-01-2022.
	F.43/102/2021	14-01-2022	11/2/2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	
	F.43/103/2021						164.44		
9.2	F.43/104/2021						168.89		do
	F.43/105/2021	14-01-2022	11/2/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.43/106/2021						164.44		
10.1	F.43/107/2021						164.44		do
	F.43/108/2021	15-01-2022	12/2/2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.43/109/2021						164.44		
10.2	F.43/110/2021						164.44		do
	F.43/111/2021	15-01-2022	12/2/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.43/112/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER